

# BHP BILLITON IRON ORE NEWMAN TOWNSHIP ELECTRICITY SUPPLY


## ANNUAL COMPLIANCE REPORT 2015/2016

REVISION A

26/07/2016

APD Job Number: W\_APD04607

## REVISION HISTORY

Document Revision History					
Revision	Description	Prepared By	Checked By	Approved By	Date
A	Original Issue	J. Goodchild	I. Midjaja	M. Mohseni (NPER # 3861990) 	26/07/2016

## PREPARED FOR

Ben Brydson

Superintendent Electrical

HV Inland Utilities, NPI

BHP Billiton Iron Ore

T (08) 9175 3445 | M +61 428 669 982

E [Ben.Brydson@bhpbilliton.com](mailto:Ben.Brydson@bhpbilliton.com)

## RESPOND TO

Mansour Mohseni (PhD, NPER)

Manager

Earthing & Power System Engineering

APD Power

T 1300 273 797 | M 0459 996 022

E [mansour.mohseni@apdpower.com.au](mailto:mansour.mohseni@apdpower.com.au)

## Copyright

© 2016, Alliance Power and Data, All rights reserved.

This document is subject to copyright. Use, copying or transmission of this document in whole or part without the prior written permission of Alliance Power and Data constitutes an infringement of copyright.

## EXECUTIVE SUMMARY

BHP Billiton Iron Ore (BHPBIO) own and operate numerous iron ore mines located at the Pilbara region of WA, including Mt Whaleback, Mining Area C and several smaller satellite mines. The township of Newman is located approximately 1,200km to the north of Perth; and the town's electricity network is owned, governed and operated by BHPBIO Supply Authority (BHPBIO SA).

In accordance with Western Australia Electricity Industry Code 2005 (the Code), the electrical supply authority must publish a report setting out the information described in Schedule 1 of the Code, in respect to each year ending on 30<sup>th</sup> of June. This document, known as the Annual Compliance Report, is to provide the full suite of information outlined in Schedule 1 of the Code, relating to the Network Quality and Reliability of Supply.

The methodology adopted to examine compliance/non-compliance with the Code utilises two notable sources of information as follows:

1. Power quality data measured from the Newman 0.415kV network over a period of 7 calendar days or more; and
2. Outage data and other relevant information provided by the network operator (BHPBIO SA).

The Code is effectively written in four Parts plus a reporting-requirements Schedule; namely,

1. Part 1: Preliminary information associated with term of reference.
2. Part 2: Quality and reliability standards, which is further partitioned into 4 *divisions*:
3. Part 3: Payment to customers for lack of regulatory adherence.
4. Part 4: Incidental duties as a Supply Authority.
5. Schedule 1: Information to be published in this report.

This Annual Compliance Report presents the relevant parts of the Code listed above; in particular the Power Quality (PQ) criteria pertaining to Newman's 11kV feeders (a total of 7) and the reportable requirements as outlined in Part 2 and Schedule 1 of the Code, for the 2015/16 Financial Year (FY).

With regards to the PQ criteria, the **average** values of all electrical parameters logged over the monitoring period (~1 week) were found well within the limits stipulated by the Code. That is, the **average** of the following parameters are proven in compliance with the Code's requirements:

- Flicker, as per Part 3.7, Clause 3 of AS 61000:2001;
- RMS Voltage;
- Power System Frequency;
- Voltage; and
- Voltage Total Harmonic Distortion (U-THD).

Note that there are a very limited number of instances (i.e., under 0.1% of the measurement period) where the maximum magnitude of certain electrical parameters were found to exceed the limits prescribed by the Code. However, this is not deemed as a major compliance issue due to the temporary and extremely isolated nature of the instances. Also note that the number of non-compliance issues recorded for 2015/16 FY is significantly (i.e., by 5 times) smaller than those of the last FY; hence, an enhanced PQ throughout the Newman's electricity network is observed.

Reportable parameters for Newman Township Electricity Supply over the 2015/16 FY (as outlined in the 'Schedule 1' of the Code) are presented below:

- >12 hour interruptions: no interruption of over 12 hours duration is recorded for *small use customers*.
- No *small use customer* was disconnected from the network more frequent than the Code's requirements (i.e., limit of 16 interruptions per FY).
- A total of 3 complaints were received over the 2015/16 FY, which were appeared to be related to the billing issues; hence no complaints made by customer on the quality or reliability of supply.
- Within the 2015/16 FY, a total of \$13.2M (AUD) was invested by BHPBIOSA towards Newman network maintenance, reinforcement, expansion and operations works. The investment was to not only address the issues identified by the operator but also to significantly improve the quality and reliability of supply (proven efficient through site measurements and evaluation of network data).
- The key reliability indices are calculated as listed below:
  - *Customer Average Interruption Duration Index (CAIDI)* of 102 minutes – CAIDI is the average outage duration that any given customer experience (i.e., the average restoration time).
  - *System Average Interruption Frequency Index (SAIFI)* of 1.64 interruptions – SAIFI is the number of interruptions that the customers experienced.
  - *Average Service Availability Index (ASAI)* of 99.97% – ASAI is the perceived availability of the network to the customers.
  - *System Average Interruption Duration Index (SAIDI)* of 168 minutes – SAIDI is the average outage duration for each customer served.

The metering data collected from 12 locations throughout the Newman network indicate that the power quality, *as so far as is reasonably practical*, is compliant with the Code. With regards to the Reliability of the Supply, the overall network performance is deemed satisfactory and significant improvements from the previous 2014/15 FY reporting period are noted.



## LIST OF TABLES

Table 1   PQ Logger Locations .....	11
Table 2   Installation and removal dates of the PQ logger used throughout the Newman network.....	13
Table 3   Long & short-term flicker limits (extract from The Code) .....	15
Table 4   Harmonic Compatibility Level (extract from The Code) .....	15
Table 5   TC3 - Summary of non-compliant flicker measurements.....	21
Table 6   Total number of breaches of voltage fluctuation compatibility levels.....	28
Table 7   Dates and times of non-compliant short-term flicker events .....	28
Table 8   Total number of breaches of total harmonic distortion limit .....	29
Table 9   Total number of breaches of voltage level limits .....	29
Table 10   Total number of breaches of frequency limits .....	30
Table 11   Total number of premises of small customers interrupted continuously for more than 12 hours ....	31
Table 12   Total number of premises that experienced more than 16 interruptions .....	31
Table 13   Total number of formal complaints lodged to BHPBIOSA.....	32
Table 14   Total amount spent by BHPBIOSA in network improvements .....	32
Table 15   Total number and amount of payments made under Sections 18 and 19.....	33
Table 16   The average length of interruption of supply to customer premises expressed in minutes (CAIDI) ..	33
Table 17   The average number of interruptions of supply to customer premises (SAIFI) .....	34
Table 18   The average percentage of time that electricity has been supplied to customer premises (ASAI) ....	34
Table 19   The average total length of all interruptions of supply to customer premises in minutes (SAIDI) .....	34
Table 20   Percentile of the average length of interruption of supply to customer premises in 2015/2016 .....	35
Table 21   Percentile values of the number of interruptions in 2015/2016 .....	35
Table 22   Percentile values of the total length of interruptions in 2015/2016 .....	36

## LIST OF FIGURES

Figure 1   Single line diagram of the Newman township (coloured circles indicate the location of PQ loggers)	12
Figure 2   Sampling and interval recording philosophy used in the Hioki PQ loggers (from Hioki Manual)	14
Figure 3   TC1- Non-compliant even harmonics	18
Figure 4   TC2- Non-compliant even harmonics	20
Figure 5   TC3- Non-compliant even harmonics	22
Figure 6   TC3 Non-compliant odd harmonics	22
Figure 7   STS6- Non-compliant even harmonics	27
Figure 8   The average length of interruption (minutes) of supply to customers over 2015/2016 FY	35
Figure 9   Percentile graph showing the number of interruptions in 2015/2016	36
Figure 10   Percentile graph showing the total length of interruptions (SAIDI) in 2015/2016	36
Figure 11   TC1 - start of feeder – flicker measurements (Red Phase)	41
Figure 12   TC1 - start of feeder – voltage measurements (Red Phase)	41
Figure 13   TC1 - start of feeder – frequency measurements	41
Figure 14   TC1 end of feeder - flicker measurements (Red Phase)	41
Figure 15   TC1 - end of feeder – voltage measurements (Red Phase)	41
Figure 16   TC1 - end of feeder – frequency measurements	41
Figure 17   TC1 – start of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics	42
Figure 18   TC1 – start of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics	42
Figure 19   TC1 – start of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics	42
Figure 20   TC1 – start of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics	42
Figure 21   TC1 – end of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics	42
Figure 22   TC1 – end of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics	42
Figure 23   TC1 – end of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics	42
Figure 24   TC1 – end of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics	42
Figure 25   TC2 – end of feeder – flicker measurements (Red Phase)	43
Figure 26   TC2 - end of feeder – voltage measurements (Red Phase)	43
Figure 27   TC2 - end of feeder – frequency measurements	43
Figure 28   TC2 – end of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics	44
Figure 29   TC2 – end of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics	44
Figure 30   TC2 – end of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics	44
Figure 31   TC2 – end of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics	44
Figure 32   TC3 - start of feeder – flicker measurements (Red Phase)	45
Figure 33   TC3 - start of feeder – voltage measurements (Red Phase)	45
Figure 34   TC3 - start of feeder – frequency measurements	45
Figure 35   TC3 - end of feeder – flicker measurements (Red Phase)	45
Figure 36   TC3 - end of feeder – voltage measurements (Red Phase)	45
Figure 37   TC3 - end of feeder – frequency measurements	45
Figure 38   TC3 – start of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics	46
Figure 39   TC3 – start of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics	46
Figure 40   TC3 – start of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics	46
Figure 41   TC3 – start of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics	46
Figure 42   TC3 – end of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics	46
Figure 43   TC3 – end of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics	46
Figure 44   TC3 – end of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics	46
Figure 45   TC3 – end of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics	46
Figure 46   TC4 - start of feeder – flicker measurements (Blue Phase)	47

Figure 47   TC4 - start of feeder – voltage measurements (Red Phase) .....	47
Figure 48   TC4 - start of feeder – frequency measurements .....	47
Figure 49   TC4 – start of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics.....	48
Figure 50   TC4 – start of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics.....	48
Figure 51   TC4 – start of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics .....	48
Figure 52   TC4 – start of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics .....	48
Figure 53   STS1 - start of feeder – flicker measurements (Red Phase) .....	49
Figure 54   STS1 - start of feeder – voltage measurements (Red Phase) .....	49
Figure 55   STS1 - start of feeder – frequency measurements (Red Phase) .....	49
Figure 56   STS1 - end of feeder – flicker measurements (White Phase).....	49
Figure 57   STS1 - end of feeder – voltage measurements (Red Phase) .....	49
Figure 58   STS1 - end of feeder – frequency measurements .....	49
Figure 59   STS1 - start of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics.....	50
Figure 60   STS1 – start of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics .....	50
Figure 61   STS1 – start of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics .....	50
Figure 62   STS1 – start of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics .....	50
Figure 63   STS1 - end of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics .....	50
Figure 64   STS1 – end of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics .....	50
Figure 65   STS1 – end of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics.....	50
Figure 66   STS1 – end of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics.....	50
Figure 67   STS2 - start of feeder – flicker measurements (Red Phase) .....	51
Figure 68   STS2 - start of feeder – voltage measurements (Red Phase) .....	51
Figure 69   STS2 - start of feeder – frequency measurements .....	51
Figure 70   STS2 - end of feeder – flicker measurements (White Phase).....	51
Figure 71   STS2 - end of feeder – voltage measurements (Red Phase) .....	51
Figure 72   STS2 - end of feeder – frequency measurements .....	51
Figure 73   STS2 - start of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics.....	52
Figure 74   STS2 – start of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics .....	52
Figure 75   STS2 – start of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics .....	52
Figure 76   STS2 – start of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics .....	52
Figure 77   STS2 - end of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics .....	52
Figure 78   STS2 – end of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics .....	52
Figure 79   STS2 – end of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics.....	52
Figure 80   STS2 – end of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics.....	52
Figure 81   STS6 - start of feeder – flicker measurements (Red Phase) .....	53
Figure 82   STS6 - start of feeder – voltage measurements (Red Phase) .....	53
Figure 83   STS6 - start of feeder – frequency measurements .....	53
Figure 84   STS6 - end of feeder – flicker measurements (Blue Phase) .....	53
Figure 85   STS6 - end of feeder – voltage measurements (Red Phase) .....	53
Figure 86   STS6 - end of feeder – frequency measurements .....	53
Figure 87   STS6 - start of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics.....	54
Figure 88   STS6 – start of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics .....	54
Figure 89   STS6 – start of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics .....	54
Figure 90   STS6 – start of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics .....	54
Figure 91   STS6 – end of feeder – 3 <sup>rd</sup> to 13 <sup>th</sup> (odd) harmonics .....	54
Figure 92   STS6 – end of feeder – 15 <sup>th</sup> to 25 <sup>th</sup> (odd) harmonics .....	54
Figure 93   STS6 – end of feeder – 2 <sup>th</sup> to 12 <sup>th</sup> (even) harmonics.....	54
Figure 94   STS6 – end of feeder – 14 <sup>th</sup> to 24 <sup>th</sup> (even) harmonics.....	54

## 1. INTRODUCTION

The township of Newman is located approximately 1,200km to the north of Perth; the town's electricity network is owned, governed and operated by BHP Billiton Iron Ore Supply Authority (BHPBIOSA). The network encompasses the township of Newman, Newman Airport, Capricorn Roadhouse, town water supply bore field, Mt Whaleback iron ore mine, and several smaller satellite mines in the adjacent areas.

At present, the township of Newman includes 2,938 registered premises comprised of a mixture of residential and commercial customers (compared to 2,546 customers for 2014/15 FY).

According to Western Australia Electricity Industry (Network Quality and Reliability of Supply) Code 2005 (the Code), an electricity distributor must prepare a report setting out the information described in Schedule 1 of the Code, in respect to each year ending on 30 June.

This *Annual Compliance Report* presents all information required by "Schedule 1 – Information to be published", relating to supply of electricity, for the period of 1<sup>st</sup> July 2015 to 30<sup>th</sup> of June 2016. Measurement information is based on sampled data outlined in Section 6, whereas outage information is based on data provided by BHPBIOSA.

The compliance statistical analysis has focused solely on Newman Township and the key infrastructure adjacent to the township. The electrical network supplying the BHPBIO mining operation and the surrounding mine leases have not been assessed in this report.

## 2. ASSUMPTIONS

The terminologies used throughout this compliance report are as defined in the Western Australia Electricity Industry (Network Quality and Reliability of Supply) Code 2005 (The Code).

The logging information gathered over the limited period is indicative of the performance of the network over the complete financial year (2015/2016 FY).

### 3. METHODOLOGY

The electricity supply compliance review entailed the following processes:

1. The temporary Installation of PQ loggers at the beginning and end of the 11kV feeders emanating from the Town and Southtown Substations (a total of 12 loggers, 2 for each feeder, with the exception of feeders TC2 and TC4 where a single PQ logger was installed). Each PQ logger was installed on the low voltage (LV) side of pad-mounted transformers. The measuring period lasted for between 7 to 8 days in the months between March 2016 and April 2016. The PQ measurements were undertaken in accordance with AS 61000.4.30:2007, Annex A (Power Quality Measurements).
2. Interpretation and analysis of the logged PQ data using HIOKI 3196 & 3198 PQ Analysers.
3. The receipt of the following information from BHPBIOSA:
  - Network outage information for planned and forced outages for the Newman Township during the 2015/2016 FY as well as information on customer complaints.
  - Expenditure information as a consequence of network complaints or programs directed to improve reliability or power quality of the network.
4. Identification of any breaches of The Code's provisions and Electricity Act 1945.
5. Statistical analyses and review of network performance.
6. Preparation of a compliance report that fulfils the requirements outlined in The Code.

## 4. NEWMAN TOWNSHIP PQ MONITORING

### 4.1.PQ Device Specification

The equipment used to undertake the PQ logging were a mixture of HIOKI 3198 and HIOKI 3196 PQ Analysers. HIOKI 3198 is the updated iteration of HIOKI 3196 but both types of loggers are practically identical in terms of their features, functionality, and user interface.

The HIOKI devices can measure multiple waveforms and transient events simultaneously using 3 voltage channels and 4 current channels per device. The device is compliant with AS61000-4-30 Ed 2 Class A, which specifies compatibility with industry standard PQ parameters (further information pertaining to the HIOKI 3198 is provided in Appendix A ).

The measurements obtained for the loggers are then extracted and analysed with the accompanying analysis software (HIOKI 9624).

### 4.2.PQ Devices

#### 4.2.1. Locations

A total of 12 PQ loggers were deployed at pre-determined locations on TC1, TC2, TC3, TC4, STS1, STS2, and STS6 feeders, as listed in Table 1 (2 logger at each feeder with the exception of TC2 and TC4 where a single PQ logger was installed).

Figure 1 presents a colour-coded single line diagram of the 7 Newman township feeders. Hatched circles indicate the locations at which the PQ loggers were temporary located.

The loggers were installed on the LV secondary side of the transformers. Due to the difficulty to install the loggers on the LV side of pole-top transformer, all of locations were associated with pad-mounted substations.

**Table 1 | PQ Logger Locations**

Zone Sub	Feeder	Location at the Start	Location at the End
Township	TC1	PS86 Red Sands	T68 Capricorn Oval
Township	TC2	-	PS14 Bondini Drive
Township	TC3	PS108 Kurra Subdivision	PS69 Giles Avenue
Township	TC4	PS125 Bubbacurry Loop	-
South Town	STS1	PS94 Pardoo Street	PS96 Pardoo Street
South Town	STS2	PS60 Forrest Avenue	PS70 Jabbarup Crescent
South Town	STS6	TX12000 Warehouse	PS120 Newman Drive






Figure 1 | Single line diagram of the Newman township (coloured circles indicate the location of PQ loggers)



#### 4.2.1. In-services Period

Table 2 presents the times and dates of when the PQ loggers were installed and removed from the Newman LV network by BHPBIOSA.

**Table 2 | Installation and removal dates of the PQ logger used throughout the Newman network**

Zone Subs	Feeder	Start or End of Feeder	Date Installed	Date Removed
Township	TC1	Start	31/03/2016 13:05	8/04/2016 10:22
		End	31/03/2016 14:21	7/04/2016 16:43
	TC2	Start	-	-
		End	31/03/2016 7:45	8/04/2016 10:57
	TC3	Start	30/03/2016 10:15	8/04/2016 13:24
		End	30/03/2016 9:00	7/04/2016 14:35
	TC4	Start	31/03/2016 8:20	7/04/2016 14:57
		End	-	-
South Town	STS1	Start	30/03/2016 13:40	7/04/2016 10:55
		End	30/03/2016 14:00	7/04/2016 12:06
	STS2	Start	30/03/2016 11:40	7/04/2016 12:23
		End	30/03/2016 13:20	7/04/2016 12:37
	STS6	Start	31/03/2016 9:56	8/04/2016 14:38
		End	31/03/2016 17:15	8/04/2016 11:48

#### 4.3.PQ Device Setup

The setup of the PQ loggers was as per the relative HIOKI instruction manual.

As shown in the frequency and voltage time-based PQ plots in Appendix B , three values have been logged and plotted: the maximum RMS, the average RMS and the minimum RMS value over the recording interval. The recording interval setup in the PQ loggers was 5 minutes, with the exception of flicker which uses 10 minute intervals. That is, over the course of the in-service days the PQ loggers sampled various time-based parameters (e.g., Hz, U and I) at 5 Hz; and at the end of every 5 minute sampling interval the 3 abovementioned RMS values were recorded.

Figure 2 is an extract from the HOIKI instruction manual depicting the sampling and interval-recording of maximum, average and minimum RMS values.




Figure 2 | Sampling and interval recording philosophy used in the Hioki PQ loggers (from Hioki Manual)

#### 4.4.PQ Device Installation Checklist

For each of the 12 PQ loggers which were installed by BHPBIOSA personnel, a PQ Logger Installation Checklist was supplied by APD. Upon completing individual logger's setup, the check sheets were to be completed and signed by the installation supervisor (all received and reviewed by APD).

Refer to Appendix C for copies of the completed checklists.

## 5. COMPLIANCE REQUIREMENTS

This section summarises the *Compatibility Levels* by which a ‘Distributor’s’ electrical network is to comply with, as outlined by the Code.

### 5.1. Voltage Fluctuations

#### 5.1.1. Flicker

The Code specifies that flicker shall comply with long- and short-term flicker ‘compatibility levels’ as per AS61000:2001. The compatibility levels are shown in Table 3, and are a measure of the voltage quality limits over a 10 minute and 2 hour interval for short- (*P<sub>st</sub>*) and long-term (*P<sub>lt</sub>*) flicker.

**Table 3 | Long & short-term flicker limits (extract from The Code)**

Compatibility levels	
<i>P<sub>st</sub></i>	1.0
<i>P<sub>lt</sub></i>	0.8

#### 5.1.2. Voltage Levels

According to AS60038-2000 Standard Voltages Section 2, the voltage levels of the electrical network must be maintained at +10% and -6% of the supply voltage of 230V single-phase.

### 5.2. Frequency

The Code specifies the frequency fluctuation shall adhere to the Electricity Act 1945 with the level to be maintained at +/-2.5% of 50Hz.

### 5.3. Voltage Total Harmonic Distortion

The Code specifies the voltage total harmonic distortion (U-THD) is to be kept under 8%.

Individual odd and even harmonic components are not to exceed the figures shown in Table 4.

**Table 4 | Harmonic Compatibility Level (extract from The Code)**

Compatibility levels for harmonic voltages (in percent of the nominal voltage)					
Odd harmonics non multiple of 3		Odd harmonics multiple of 3		Even harmonics	
Order h	Harmonic voltage %	Order h	Harmonic voltage %	Order h	Harmonic voltage %
5	6	3	5	2	2
7	5	9	1.5	4	1
11	3.5	15	0.3	6	0.5
13	3	21	0.2	8	0.5
17	2	>21	0.2	10	0.5
19	1.5			12	0.2
23	1.5			>12	0.2
25	1.5				
>25	0.2+1.3 (25/h)				
Note — Total harmonic distortion (THD): 8%					

## 5.4. Power Industry Reliability Indicators

As per Schedule 1, Clause 11 (a) to (d) of The Code, a number of reliability indicators (e.g. interruption durations and quantity of interruptions) are required to be reported. To achieve The Code's requirement, the following standard utility reliability indices have been used.

### 5.4.1. Customer Average Interruption Duration Index (CAIDI)

Customer Average Interruption Duration Index is defined as the sum of the duration of each customer interruption (in minutes) divided by the number of distribution customers served.

$$CAIDI_{Minutes} = \frac{\sum \text{Customer Interruption Durations}}{\sum \text{Customer Interruptions}} = \frac{SAIDI}{SAIFI}$$

### 5.4.2. System Average Interruption Frequency Index (SAIFI)

System Average Interruption Frequency Index is defined as the sum of the frequency of each sustained distribution customer interruption (in interruption events) attributable to the distribution system divided by the number of distribution customers served.

$$SAIFI_{Interruptions} = \frac{\sum \text{Number of Sustained DX Customer Interruptions}}{\text{Number of DX Customers Served}}$$

### 5.4.3. Average Service Availability Index (ASAI)

Average Service Availability Index is the percentage of time that the service is available to the networks' customers in a reportable year.

$$ASAI_{Percent} = 1 - \frac{SAIDI_{Hours}}{8760}$$

### 5.4.4. System Average Interruption Duration Index (SAIDI)

System Average Interruption Duration Index is defined as the sum of the duration of each sustained distribution customer interruption (in minutes) attributable to the distribution system divided by the number of distribution customers served.

$$SAIDI_{Minutes} = \frac{\sum \text{Sustained DX Customer Interruption Durations}}{\text{Number of DX Customers Served}}$$

## 6. Site Measurements (PQ Loggers Data)

The following sections describe the results and notable PQ events which have been recorded by the loggers for each of the 7 feeders.

### 6.1. Feeder TC1

The PQ logger at the start of the TC1 feeder was installed in the PS86 Red Sands pad-mounted substation between 31/03/2016 and 8/04/2016, thus satisfying the 7 days minimum logging duration requirement.

The PQ logger at the end of the TC1 feeder was installed in the T68 Capricorn Oval substation between 31/03/2016 and 7/04/2016, thus satisfying the 7 days minimum logging duration requirement.

As shown in Figure 1 (orange feeder), TC1 originates from the Township Substation. It is a feeder that supplies a number of old distribution substations.

#### 6.1.1. Flicker

The logged flicker data for the start and end of feeder-TC1 are shown in Figure 11 and Figure 14 of Appendix B (page 41) respectively. There were no flicker limit events causing the flicker level to breach The Code's limits (i.e., full compliance with the Code requirements).

#### 6.1.2. Voltage

The logged voltage level data for the start and end of feeder-TC1 are shown in Figure 12 and Figure 15 in Appendix B (page 41) respectively. There were no voltage limit events causing the voltage level to breach The Code's limits (i.e., full compliance with the Code requirements).

#### 6.1.3. Frequency

The logged frequency data for the start and end of feeder-TC1 are shown in Figure 13 and Figure 16 in Appendix B (page 41) respectively. There were no notable frequency limit events which caused the frequency level to breach The Code's limits (i.e., full compliance with the Code requirements).

#### 6.1.4. Harmonics

The logged harmonic data for the start and end of feeder TC1 are shown in Figure 17 through Figure 24 in Appendix B (page 42). Note that there are very few non-compliant harmonics measured by the PQ loggers at once instance (on 7<sup>th</sup> of April 2016), which are of isolated nature and a very small fraction of the measurement period.

A summary of non-compliant harmonics and the scale of non-compliance are shown in Figure 3. Given the rare, temporary and random nature of the breaches, there are not deemed of any practical concern (i.e., not deemed as compliance issues).

Also note that the harmonic compliance issues observed for 2015/16 FY are over 10 times smaller/less frequent than those recorded for 2014/15 FY, hence a significant improvement in the quality of supply is noted.

TC1 - Non-Compliant Even Harmonics




Figure 3 | TC1- Non-compliant even harmonics



## 6.2. Feeder TC2

The PQ logger on the TC2 feeder was installed in the PS14 Bondini Drive substation between 31/03/2016 and 8/04/2016, thus satisfying the 7 days minimum logging duration requirement.

As shown in Figure 1 (cyan-coloured feeder), TC2 originates from the Township Substation.

### 6.2.1. Flicker

The logged flicker data for the end of feeder-TC2 are shown in Figure 25 of Appendix B (page 43). There were no flicker limit events which caused the flicker level to breach The Code's limits, hence full compliance with the Code requirements.

### 6.2.2. Voltage

The logged voltage level data for the end of feeder-TC2 are shown in Figure 26 in Appendix B (page 43). There were no voltage limit events which caused the voltage level to breach The Code's limits, hence full compliance with the Code requirements.

### 6.2.1. Frequency

The logged frequency data for the end of feeder-TC2 are shown in Figure 27 in Appendix B (page 43). There were no notable frequency limit events which caused the frequency level to breach The Code's limits, hence full compliance with the Code requirements.

### 6.2.1. Harmonics

The logged harmonic data for the start and end of feeder TC2 are shown in Figure 28 through Figure 31 in Appendix B (page 44). Note that there are very few non-compliant harmonics measured by the PQ loggers at once instance (on 7<sup>th</sup> of April 2016)

A summary of non-compliant harmonics and the scale of non-compliance are shown in Figure 4. Given the rare, temporary and random nature of the breaches, there are not deemed of any practical concern (i.e., not deemed as compliance issues).

Also note that the harmonic compliance issues observed for 2015/16 FY are over 10 times smaller/less frequent than those recorded for 2014/15 FY, hence a significant improvement in the quality of supply is noted.

TC2 - Non-Compliant Even Harmonics




Figure 4 | TC2- Non-compliant even harmonics

### 6.3. Feeder TC3

The PQ logger at the start of the TC3 feeder was installed in the PS108 Kurra Subdivision Area pad-mounted substation between 30/03/2016 and 8/04/2016, thus satisfying the 7 days minimum logging duration requirement.

The PQ logger at the end of the TC3 feeder was installed in the PS69 Giles Avenue substation between 30/03/2016 and 7/04/2016, thus satisfying the 7 days minimum logging duration requirement.

As shown in Figure 1 (purple-coloured feeder), TC3 originates from the Township Substation.

#### 6.3.1. Flicker

The logged flicker data for the start and end of feeder-TC3 are shown in Figure 32 and Figure 35 of Appendix B (page 45), respectively.

Notable non-compliant flicker events and their respective magnitudes and effected-phases are shown in Table 5, which is under 0.1% of the measurement period (hence deemed as no major compliance issues). Comparison of the results with those obtained last FY indicates improved (i.e., attenuated) flicker level in the 2015/16 FY.

**Table 5 | TC3 - Summary of non-compliant flicker measurements**

Date	Non-compliant Short Term Flicker Events	
	Feeder – TC3	
	Start of Feeder	End of Feeder
	<i>Pst</i>	<i>Pst</i>
30/03/2016 15:20:00		1.03 (W Phase)

#### 6.3.1. Voltage Levels

The logged voltage level data for the start and end of feeder-TC3 are shown in Figure 33 and Figure 36 in Appendix B (page 45) respectively. There were no notable voltage limit events which caused the voltage level to breach The Code's limits, hence full compliance with the Code.

#### 6.3.2. Frequency

The logged frequency data for the start and end of feeder-TC3 are shown in Figure 34 and Figure 37 in Appendix B (page 45) respectively. There were no notable frequency limit events which caused the frequency level to breach The Code's limits, hence full compliance with the Code.

#### 6.3.1. Harmonics

The logged harmonic data for the start and end of feeder TC3 are shown in Figure 38 through Figure 45 in Appendix B (page 46). Of particular interest is the non-compliant harmonics that were measured by the PQ loggers (a very small fraction of the measurements). A summary of non-compliant even harmonics and the scale of their non-compliance are shown in Figure 5 and Figure 6 – which are all notably smaller and less frequent than those recorded over 2014/15 FY (hence improved quality of supply).




Figure 5 | TC3- Non-compliant even harmonics




Figure 6 | TC3 Non-compliant odd harmonics

## 6.4. Feeder TC4

The PQ logger at the start of the TC4 feeder was installed in the PS125 Bubbacurry Loop pad-mounted substation between 31/03/2016 and 07/04/2016.

As shown in Figure 1 (light-green coloured feeder), TC4 originates from the Township Substation.

### 6.4.1. Flicker

The logged flicker data for the start of feeder-TC4 are shown in Figure 46 of Appendix B (page 47). There were no flicker limit events which caused the flicker level to breach The Code's limits, hence full compliance with the Code requirements.

### 6.4.2. Voltage

The logged voltage level data for the start of feeder-TC4 are shown in Figure 47 in Appendix B (page 47). There were no notable voltage limit events which caused the voltage level to breach The Code's limits, hence full compliance with the Code.

### 6.4.3. Frequency

The logged frequency data for the start of feeder-TC4 are shown in Figure 48 in Appendix B (page 47). There were no notable frequency limit events which caused the frequency level to breach The Code's limits, hence full compliance with the Code.

### 6.4.1. Harmonics

The logged harmonic data for the start and end of feeder TC4 are shown in Figure 49 through Figure 52 in Appendix B (page 48). There were no notable individual harmonic limit events which caused the individual harmonic levels to breach The Code's limits, hence full compliance with the Code.

## 6.5. Feeder STS1

The PQ logger at the start of the STS1 feeder was installed in the PS94 Pardoo Street pad-mounted substation between 30/03/2016 and 7/04/2016, thus satisfying the 7 days minimum logging duration requirement.

The PQ logger at the end of the STS1 feeder was installed in PS96 Pardoo Street substation between 30/03/2016 and 7/04/2016, thus satisfying the 7 days minimum logging duration requirement.

As shown in Figure 1 (green-coloured feeder), STS1 originates from the Southtown Substation.

### 6.5.1. Flicker

The logged flicker data for the start and end of feeder-STs1 are shown in Figure 53 and Figure 56 of Appendix B (page 49), respectively. There were no flicker limit events which caused the flicker level to breach The Code's limits, hence full compliance with the Code requirements.

### 6.5.1. Voltage

The logged voltage level data for the start and end of feeder-STs1 are shown in Figure 54 and Figure 57 (page 49), respectively. There were no notable voltage limit events which caused the voltage level to breach The Code's limits, hence full compliance with the Code.

### 6.5.1. Frequency

The logged frequency data for the start and end of feeder-STs1 are shown in Figure 55 and Figure 58 in Appendix B (page 49) respectively. There were no notable frequency limit events which caused the frequency level to breach The Code's limits, hence full compliance with the Code.

### 6.5.1. Harmonics

The logged harmonic data for the start and end of feeder STS1 are shown in Figure 59 through Figure 66 in Appendix B (page 50). There were no notable individual harmonic limit events which caused the individual harmonic levels to breach The Code's limits, hence full compliance with the Code.

## 6.6. Feeder STS2

The PQ logger at the start of the STS2 feeder was installed in the PS60 Forrest Avenue pad-mounted substation between 30/03/2016 and 7/04/2016, thus satisfying the 7 days minimum logging duration requirement.

The PQ logger at the end of the STS2 feeder was installed in the T70 Jabbarup Crescent substation between 30/03/2016 and 7/04/2016, thus satisfying the 7 days minimum logging duration requirement.

As shown in Figure 1 (grey-coloured feeder), STS2 originates from the Southtown Substation.

### 6.6.1. Flicker

The logged flicker data for the start and end of feeder-STS2 are shown in Figure 67 and Figure 70 of Appendix B (page 51) respectively. There were no flicker limit events which caused the flicker level to breach The Code's limits, hence full compliance with the Code requirements.

### 6.6.2. Voltage

The logged voltage level data for the start and end of feeder-STS2 are shown in Figure 68 and Figure 71 in Appendix B (page 51) respectively. There were no notable voltage limit events which caused the voltage level to breach The Code's limits, hence full compliance with the Code.

### 6.6.1. Frequency

The logged frequency data for the start and end of feeder-STS2 are shown in Figure 69 and Figure 72 in Appendix B (page 51) respectively. There were no notable frequency limit events which caused the frequency level to breach The Code's limits, hence full compliance with the Code.

### 6.6.1. Harmonics

The logged harmonic data for the start and end of feeder STS2 are shown in Figure 73 through Figure 80 in Appendix B (page 52). There were no notable individual harmonic limit events which caused the individual harmonic levels to breach The Code's limits, hence full compliance with the Code.



## 6.7. Feeder STS6

The PQ logger at the start of the STS6 feeder was installed in the TX12000 Warehouse pad-mounted substation between 31/03/2016 and 8/04/2016, thus satisfying the 7 days minimum logging duration requirement.

The PQ logger at the end of the STS6 feeder was installed in the PS121 Newman Drive substation between 31/03/2016 and 8/04/2016, thus satisfying the 7 days minimum logging duration rule.

As shown in Figure 1 (yellow-coloured feeder), STS6 originates from the Southtown Substation.

### 6.7.1. Flicker

The logged flicker data for the start and end of feeder- STS6 are shown in Figure 81 and Figure 84, respectively. There were no flicker limit events which caused the flicker level to breach The Code's limits, hence full compliance with the Code requirements.

### 6.7.2. Voltage

The logged voltage level data for the start and end of feeder-STS6 are in Figure 82 and Figure 85 in Appendix B (page 53) respectively. There were no notable voltage limit events which caused the voltage level to breach The Code's limits, hence full compliance with the Code.

### 6.7.1. Frequency

The logged frequency data for the start and end of feeder-STS6 are shown in Figure 83 and Figure 86 in Appendix B (page 53) respectively. There were no notable frequency limit events which caused the frequency level to breach The Code's limits, hence full compliance with the Code.

### 6.7.1. Harmonics

The logged harmonic data for the start and end of feeder STS6 are shown in Figure 87 through Figure 94 in Appendix B (page 54). Of particular interest is the non-compliant harmonics measured by the PQ loggers, which is a very small fraction of the measurement data. A summary of non-compliant harmonics and the scale of their non-compliance are shown in Figure 7.

STS6 - Non-Compliant Even Harmonics




Figure 7 | STS6- Non-compliant even harmonics

## 7. RESPONSE TO THE CODE REQUIREMENTS

This section contains all of the information required for compliance reporting as detailed in The Code “Schedule 1 - Information to be published” and “Part 2 – Quality and reliability standards”.

### 7.1. Quality and Reliability Standards (Part 2)

#### 7.1.1. Voltage Fluctuations (Part 2 Division 1 Quality Standards Section 6(2))

The voltage fluctuations (flicker) of electricity supplied must not exceed the compatibility levels for long-term and short-term flicker as described in Section 5.1.1.

The PQ logging results indicate a small number of voltage fluctuation breaches on the TC3 feeder supplying part of the township network during the logged periods. Table 6 presents the results for the previous three reporting periods together with the 2015/2016 result. The dates and times of their occurrence are shown in Table 7.

**Given the results presented in Table 6, a significant improvement is observed over the 2015/16 FY compared to the measurements of the years before.**

Table 6 | Total number of breaches of voltage fluctuation compatibility levels

Description	Reportable Period			
	2012/2013	2013/2014	2014/2015	2015/2016
Total number of breaches of <i>Pst</i>	5	79	5	1
Total number of breaches of <i>Plt</i>	1	72	1	0

Table 7 | Dates and times of non-compliant short-term flicker events

Date	Time
30/03/2016	15:20:00

#### 7.1.2. Harmonics (Part 2 Division 1 Quality Standards Section 7)

Within the Code, there are two measures for assessing the power quality of the Newman network. The two measures are:

- 1 Assessment of individual harmonics and a comparison of their magnitudes against the table in Part 2, Division 1, Section 7 of The Code; and
- 2 Assessment of the calculated Voltage Total Harmonic Distortion (U-THD) and a comparison of its magnitude with The Code’s compliant value of 8%.

##### 7.1.2.1. Individual Voltage Harmonics

Individual, non-compliant harmonics for each respective feeder are already presented in Section 6.

#### 7.1.2.2. Voltage Total Harmonic Distortions

The voltage harmonic distortion levels of electricity supplied must not exceed the Voltage Total Harmonic Distortion (U-THD) of 8% stated in Part 2, Division 1, Section 7 of the Code. Table 8 presents the results for the previous three reporting periods together with the 2015/2016 result. In the 2015/2016, no events occurred where the *maximum* U-THD was greater than the 8% limit. The *average* of the U-THD was consistently well within the 8% limit.

**Table 8 | Total number of breaches of total harmonic distortion limit**

Description	Reportable Period			
	2012/2013	2013/2014	2014/2015	2015/2016
Total number of breaches of Voltage Total Harmonic Distortion (U-THD)	0	0	1	0

#### 7.1.3. Voltage Level Compliance (Part 2 Division 2 Quality Standards Section 8 Note (a))

This information is not required as part of the reporting requirements of The Code. It has been included here to provide a more complete indication of the power quality of supply.

According to AS60038-2000 Standard Voltages Section 2, the voltage levels of the electrical network must be maintained at +10% and -6% of the supply voltage of 230V single-phase.

As the voltage measurements were taken at the secondary (LV) side of the pad-mounted transformers located at the beginning and the end of each feeder supplying the township, the voltage level at the customer's connection point would be lower than the logged results. The voltage drop due to customers' loads must be limited to 5%, in accordance to AS 3000. The lowest averaged minimum voltage levels recorded during the PQ logging period was 240V (end of TC1). Therefore, it is expected that the voltage level at the customer's connection would be within the required range.

Table 9 presents the results for the previous three reporting periods together with the 2015/2016 result. In 2015/2016, there were no instances where the voltage level breached the voltage limits.

**Table 9 | Total number of breaches of voltage level limits**

Description	Reportable Period			
	2012/2013	2013/2014	2014/2015	2015/2016
Total number of breaches of voltage limits	8	0	2	0

#### 7.1.4. Frequency Compliance (Part 2 Division 2 Quality Standards Section 8 Note (b))

According to Electricity Act 1945 Section 25(1)(d), the frequency of electricity supplied must be maintained at  $\pm 2.5\%$  of the frequency of 50 cycles per second. This information is not required as part of the reporting requirements of The Code. It has been included here to provide a more complete indication of supply PQ.

Table 10 presents the results for the previous three reporting periods together with the 2015/2016 result. For the 2015/2016 PQ logging period, there were no instances where the frequency breached the required limits.

**Table 10 | Total number of breaches of frequency limits**

Description	Reportable Period			
	2012/2013	2013/2014	2014/2015	2015/2016
Total number of breaches of frequency limits	0	0	1	0

#### 7.2. Remedial actions taken for breaches of provisions (Schedule 1 Item 4 (b))

Newman BHPBIOSA is found very pro-active in establishing and executing asset replacement programs in order to sustain and improve power quality and reliability.

To ensure compliance to Australian Standards, BHPBIOSA proactively undertake annual PQ logging on the 11kV supply feeders from both Whaleback and Township Substations during the summer period. Improvements are continuously implemented based on the PQ logging data results, and complaints received from customers related to power quality issues.

Asset upgrades including:

- Replacement of 6 distribution transformers in the Township of Newman due to ageing or defects.
- The addition of a Transformer with AVR/Tap Change to reduce voltage related issues associated from the Whaleback supply.
- The installation of a Capacitor Bank for Whaleback.

Additionally, a program to reduce bird strike related trips has been successfully implemented which has significantly reduced the number of outages.

In addition to the asset upgrade programs executed over the 2015/16 FY, BHPBIOSA have managed to improve the internal work process, yielding improved quality and reliability of supply. A brief example of process improvement works already completed or currently in-progress by BHPBIOSA includes the following:

- Purchase of a software package to automate the inspection record keeping, generation of reports and notices required (currently in progress – to be completed by the next FY)
- Upgraded ISP (Inspection System Plan) and ISP Manual documents, already submitted to DMP for approval
- Distribution Maintenance Strategy document re-developed to consider frequency, criticality and failure mode of the equipment, hence achieving smarter investment and work plan.

### 7.3. Supply interrupted (Schedule 1 Item 5)

The provisions of The Code have the following requirements:

*“The number of premises of small use customers the supply of electricity to which has been interrupted —*

*(a) for more than 12 hours continuously; or*

*(b) more than the permitted number of times, as that expression is defined in section 12(1),*

*and in the case of interruptions referred to in paragraph (a), the number of interruptions and the length of each interruption.”*

#### 7.3.1. Interruptions Exceeding 12 Hours

Table 11 presents the interruptions over 12 Hours for small use customer, with no such interruptions recorded for 2015/16 FY.

**Table 11 | Total number of premises of small customers interrupted continuously for more than 12 hours**

Description	Reportable Periods			
	2012/2013	2013/2014	2014/2015	2015/2016
Total number of premises that experienced interruptions more than 12 hours	1	5	0	0

#### 7.3.2. Frequent Interruptions

The permitted number of times a customer can be disconnected in the Newman Township is 16 interruptions as per Section 12. (1) (b) of the Code. Analysis of BHPBIOSA's outage logs presented in Table 12 indicates that the no customers were disconnected more than 16 times.

**Table 12 | Total number of premises that experienced more than 16 interruptions**

Description	Reportable Periods			
	2012/2013	2013/2014	2014/2015	2015/2016
Total number of premises that experienced interruptions more than 16 times	0	0	0	0

#### 7.4. Number of complaints received (Schedule 1 Item 6 and Item 10)

According to Schedule 1, “complaint” means that a provision of Electricity Code 2005 Part 2; or an instrument made under Electricity Code 2005 Section 14(3), has not been, or is not being, complied with. For the reporting period, a total of 3 complaints were made, with the information provided in Table 6 to Table 12 it is assumed that each complaint was associated with billing issues, hence no complaints received on the reliability or quality of the supply.

Table 13 presents the results for the previous three reporting periods together with the 2015/2016 result.

**Table 13 | Total number of formal complaints lodged to BHPBIOSA**

Description	Reportable Periods			
	2012/2013	2013/2014	2014/2015	2015/2016
Total number of formal complaints received	0	0	0	0

#### 7.5. Complaints received in each discrete area (Schedule 1 Items 7 & 10)

The township of Newman is supplied from an integrated network and there are no discrete areas.

#### 7.6. Total amount spent addressing complaints (Schedule 1 Items 8 & 10)

There has been no technical complaint over the 2015/16 FY that required BHPBIO’s action. However, the complaints related to bill issues which were resolved by the retailing and billing contractor hired by BHPBIOSA (i.e., MBC Global).

#### 7.7. Investments over 2015/2016 FY to improve the Reliability of Supply & Power Quality

Table 14 shows the total AUD amount spent in improving the supply quality and reliability and to cater for network expansion. The changes in the network investment over various FY is partly attributed to the re-structuring works taken place in BHPBIOSA over the course of last few years.

**Table 14 | Total amount spent by BHPBIOSA in network improvements**

Description	Reportable Periods			
	2012/2013	2013/2014	2014/2015	2015/2016
Total amount spend in dollars (AUD)	\$13.68 million	\$14.90 million	\$16.90 million	\$13.20 million



## 7.8. Number and Total amount of payments made (Schedule 1 Items 9 & 10)

This section outlines the total number of payments and the amount of those payments made by BHPBIOSA under Sections 18 and 19 of the Code. That is payment for failure to give the require notice of planned interruptions and payments for supply interruptions exceeding 12 hours. There was no supply interruptions exceeding 12 hours or small customer being disconnected for over 16 times, hence no payment needed to be made. Table 15 presents the results for the previous three reporting periods together with the 2015/2016 result.

**Table 15 | Total number and amount of payments made under Sections 18 and 19**

Description	Reportable Periods			
	2012/2013	2013/2014	2014/2015	2015/2016
Total number of payments	0	0	0	0
Total amount of payments (AUD)	0	0	0	0

## 7.9. Reliability of Supply (Schedule 1 Item 11)

This section covers the requirements of Item 11 of Schedule 1 of The Code, as reproduced below:

1. *“For each discrete area —*
  - (a) the average length of interruption of supply to customer premises expressed in minutes;*
  - (b) the average number of interruptions of supply to customer premises;*
  - (c) the average percentage of time that electricity has been supplied to customer premises; and*
  - (d) the average total length of all interruptions of supply to customer premises expressed in minutes.”*

In this report, the township of Newman is considered the *discrete area*.

### 7.9.1. Average interruption (Schedule 1 Items 11 (a), 12 and 13)

The average length of interruption of supply to customer premises for the Newman township electrical network is measured in minutes over the course of the 2015/2016 FY and is shown in Table 16 (fairly identical to the average interruption duration for the last 5 years).

**Table 16 | The average length of interruption of supply to customer premises expressed in minutes (CAIDI)**

Description	Reportable Period				
	2012/2013	2013/2014	2014/2015	2015/2016	Average
Average length of interruptions - CAIDI (minutes)	95	132	80	102	102

### 7.9.2. Average number of interruptions (Schedule 1 Items 11 (b), 12 and 13)

The average number of interruptions of supply to customer premises for the township of Newman over the course of the 2015/2016 FY is shown in Table 17 (which appears to be smaller than the average of 2.72 interruptions per year, calculated for the last 5 years).

**Table 17 | The average number of interruptions of supply to customer premises (SAIFI)**

Description	Reportable Period				
	2012/2013	2013/2014	2014/2015	2015/2016	Average
Average supply interruptions – SAIFI (No. of Interruptions)	2.59	2.40	4.23	1.64	2.72

### 7.9.3. Average percentage of time electricity supplied (Schedule 1 Items 11 (c), 12 and 13)

The average percentage of time that electricity has been supplied to customer premises over the course of the 2015/2016 FY is shown in Table 18.

**Table 18 | The average percentage of time that electricity has been supplied to customer premises (ASAI)**

Description	Reportable Period				
	2012/2013	2013/2014	2014/2015	2015/2016	Average
Average number of supply interruptions ASAI (Percentage of)	99.95%	99.94%	99.94%	99.97%	99.95%

### 7.9.4. Average total length of all interruptions (Schedule 1 Items 11 (d), 12 and 13)

The average total length of all interruptions of supply to customer premises, expressed in minutes, is shown in Table 19 (comparatively better than the average of the last 5 years).

**Table 19 | The average total length of all interruptions of supply to customer premises in minutes (SAIDI)**

Description	Reportable Period				
	2012/2013	2013/2014	2014/2015	2015/2016	Average
SAIDI (minutes)	245	318	339	168	268

## 7.10. Percentile Values (Schedule 1 Items 14 and 15)

This section outlines the response to schedule 1 items 14 and 15 of the Code. An extract from the code requirements is shown below:

Item 14: *“For customer premises in each discrete area, an estimate of the 25th, 50th, 75th, 90th, 95th, 98th and 100th percentile values of —*

*(a) the average length of interruption referred to in item 11(a);*

*(b) the number of interruptions; and*

*(c) the total length of interruptions.”*


Item 15: *“For each category of information in item 14(a), (b) and (c), a graph showing the distribution of customer premises across the range of that category.”*

### 7.10.1. Percentile – Average Length of Interruption

As required by ‘Schedule 1’ of The Code, Table 20 presents the CAIDI results on a percentile basis. Note that for majority (98%) of the outages experienced by customers in Newman Township, the average restoration time is 81 minutes but this would increase to 102 minutes if the remaining 2% of the outages are also included in the calculations.

**Table 20 | Percentile of the average length of interruption of supply to customer premises in 2015/2016**

Description	25th	50th	75th	90th	95th	98th	100th
Average Length of Interruption (CAIDI)	81	81	81	81	81	81	102



**Figure 8 | The average length of interruption (minutes) of supply to customers over 2015/2016 FY**

### 7.10.2. Percentile - Number of interruptions

As required by ‘Schedule 1’ of The Code, Table 21 presents the SAIFI results on a percentile basis.

**Table 21 | Percentile values of the number of interruptions in 2015/2016**

Description	25th	50th	75th	90th	95th	98th	100th
Number of interruptions (SAIFI)	0.6	0.6	0.6	0.6	0.6	0.6	1.6




Figure 9 | Percentile graph showing the number of interruptions in 2015/2016

#### 7.10.3. Percentile - Total Length of Interruptions

As required by 'Schedule 1' of The Code, Table 22 presents the SAIDI results on a percentile basis.

Table 22 | Percentile values of the total length of interruptions in 2015/2016

Description	25th	50th	75th	90th	95th	98th	100th
Total lengths of interruptions (SAIDI)	52	52	52	52	52	52	168




Figure 10 | Percentile graph showing the total length of interruptions (SAIDI) in 2015/2016

## 8. CONCLUSION

This report addresses all relevant parts; in particular the PQ standards pertaining to each of Newman's 11kV supply network and the reportable requirements as per Part 2 and Schedule 1 of the Code.

With regards to the PQ standards, the *average* values of all electrical parameters logged over the monitoring period of around a week were found well within the limit stipulated by the Code. That is, the *average* of the following parameter easily complied with the Code:

- Flicker, as per Part 3.7, Clause 3 of AS 61000:2001
- RMS Voltage
- Power System Frequency
- Voltage
- Voltage Total Harmonic Distortion (U-THD)

Note that there are a very limited number of instances (i.e., under 0.1% of the measurement period) where the maximum magnitude of certain electrical parameters were found to exceed the limits prescribed by the Code. However, this is not deemed as a major compliance issue due to the temporary and extremely isolated nature of the instances. Also note that for large majority of limits invested, site measurements indicate significant improvements in 2015/16 FY compared to those measured for the years before.

Reportable parameters for Newman Township Electricity Supply over the 2015/16 FY (as outlined in the 'Schedule 1' of the Code) are presented below:

- >12 hour interruptions: no interruption of over 12 hours duration is recorded for *small use customers*.
- No *small use customer* was disconnected from the network more frequent than the Code's requirements (i.e., limit of 16 times).
- A total of 3 complaints were received, which were assumed to be related to the billing issues; hence no complaints made by customer on the quality or reliability of supply.
- Within the 2015/16 FY, a total of \$13.2M (AUD) was invested by the network operator (BHPBIOSA) towards Newman network operations, maintenance and reinforcement works; to not only address the issues identified by the operator but also to significantly improve the quality and reliability of supply.
- The key reliability indices are calculated as listed below:
  - *Customer Average Interruption Duration Index (CAIDI)* of 102 minutes – CAIDI is the average outage duration that any given customer experience (i.e., the average restoration time).
  - *System Average Interruption Frequency Index (SAIFI)* of 1.64 interruptions – SAIFI is the number of interruptions that the customers experienced.
  - *Average Service Availability Index (ASAI)* of 99.97% – ASAI is the perceived availability of the network to the customers.
  - *System Average Interruption Duration Index (SAIDI)* of 168 minutes – SAIDI is the average outage duration for each customer served.

The metering data collected from 12 locations throughout the Newman network indicate that the power quality, *as so far as is reasonably practical*, is compliant with The Code.

With regards to reliability, the Supply Authority's outage data indicates that there were a number of feeder trips (including the loss of complete zone substations) which have affected the reliability indices. In some cases the substation outages were a result of human error or mal-operation of protection. In other cases, genuine backbone feeder faults have resulted in large-scale loss of customers due to the correct operation of protection.

In summary, this report finds the reliability and quality of the supply for Newman Township network in compliance with the Code's requirements; however, there are areas that require the BHPBIOSA's attention and investment to ensure improved quality of electricity supply in the upcoming years.

## APPENDIX A PQ Logging Device (HIOKI 3198)

Please refer to the following pages.



## POWER QUALITY ANALYZER PW3198

Power Measuring Instruments



*Record and Analyze Power Supply Problems Simultaneously with a Single Unit*

*The New World Standard for Power Quality Analysis*

### ■ Never Miss **the Moment**

- Detect power supply problems and perform onsite troubleshooting
- Do preventive maintenance to avert accidents by managing the power quality

### ■ **CAT IV-600V Safety Standard**

- Meets the CAT IV safety rating required to check an incoming power line
- Safe enough to measure up to 6,000Vpeak of transient overvoltage

### ■ **Easy Setup Function with PRESETS**

- Just select the measurement course, wiring, and clamps
- Automatic one-step setup based on measurement conditions

### ■ Compliant with **New International Standards**

- International power quality measurement standard IEC 61000-4-30 Edition 2 Class A
- High precision with a basic voltage measurement accuracy of 0.1%



ISO 9001  
JMI-0216



ISO14001  
JQA-E-90081



[www.hioki.com](http://www.hioki.com)

HIOKI company overview, new products, environmental considerations and other information are available on our website.



# One Single Unit Can Solve All Your Power Supply Problems



*The number of power supply problems is increasing as power systems are becoming more and more complicated - all due to the rising use of power electronics devices plus a growing installed base of large systems and distributed power supplies. The quickest way to approach these problems is to understand the situation quickly and accurately. The PW3198 PowerQuality Analyzer is ready to effectively solve your power supply problems.*

## Troubleshooting

- ✓ Understand the actual power situation at the site where the problem is occurring (e.g., the equipment malfunction, failure, reset, overheating, or burning damage).
- ✓ Ideal for troubleshooting solar and wind power generation systems, EV charge stations, smart grids, tooling machines, OA equipment (e.g., computers, printers, and UPS), medical equipment, server rooms, and electrical equipment (e.g., transformers and phase-advancing capacitors).

## Field Survey and Preventive Maintenance

- ✓ Perform long-term measurements of the power quality and study problems that are difficult to detect or that occur intermittently.
- ✓ Maintain electrical equipment and check the operation of solar and wind power generation systems.
- ✓ Manage the parameters with a control set point, such as a voltage fluctuation, flicker, and harmonic voltage.

## Power (Load) Survey

- ✓ Study the power consumption and confirm system capacity before adding load.





# Advanced Features for Safe, Simple, and Accurate Measurements

## 1

### International Standard IEC61000-4-30 Edition 2 Class A

Class A is defined in the international standard IEC61000-4-30, which specifies compatibility with power quality parameters, accuracy, and standards to enable comparison and discussion of the measurement results of different measuring instruments.

The PW3198 is compliant with the latest IEC61000-4-30 Edition 2 Class A standard. The instrument can perform measurements in accordance with the standard, including continuous gapless calculation, methods to detect events such as dip, swell, and instantaneous power failure, and time synchronization using the optional GPS box.



## 2


### CAT IV-600V Safety

The PW3198 is compliant with the measurement category CAT IV - 600V and can also safely test the incoming lines for both single-phase and three-phase power supplies.



## 3

### Easy to set up - Just select the measurement course and the PW3198 will do the rest




Simply choose the course based on the measurement objective and the necessary configurations will be set automatically.

<b>U Events</b>	Record voltage and frequency and detect errors simultaneously.
<b>Standard Power Quality</b>	Record voltage, current, frequency, and harmonic, and detect errors simultaneously.
<b>Inrush current</b>	Measure the inrush current.
<b>Recording</b>	Record only the TIME PLOT Data but do not detect errors.
<b>EN50160</b>	Perform measurements in accordance with EN50160.

## 4


### Highly Accurate, Broadband, Wide Dynamic Range Makes for Reliable Measurements

#### Voltage Measurement Range



Both low and high voltages can be measured in a single range.

#### Voltage Frequency Range




Wide range from DC voltage to 700 kHz

#### Basic Measurement Accuracy (50/60 Hz)

<b>Voltage</b>	$\pm 0.1\%$ of nominal voltage
<b>Current</b>	$\pm 0.2\%$ rdg, $\pm 0.1\%$ f.s. + Clamp-on sensor accuracy
<b>Power</b>	$\pm 0.2\%$ rdg, $\pm 0.1\%$ f.s. + Clamp-on sensor accuracy


World's highest level of basic measurement accuracy. Extremely accurate voltage measurement without the need to switch ranges.

#### Transient Overvoltage



Transient overvoltage can also be measured in a range between the maximum 6,000 V and minimum 1  $\mu$ s (2 MS/s).

#### High-order Harmonic



The PW3198 is the first power quality analyzer that can measure the high-order harmonic component of up to 80 kHz.






# PW3198 Never Misses the Moment a Power Supply Failure Occurs

The PW3198 can measure all waveforms of power, harmonic, and error events simultaneously. When a problem occurs with the equipment or system on your site, the PW3198 will help you detect the cause of the problem early and solve it quickly. You can depend on the PW3198 to monitor all aspects of your power supplies.

## Measure All Parameters at the Same Time

### Acquire the Information You Need Quickly by Switching Pages (RMS Value)

Just connect to the measurement line, and the PW3198 will simultaneously measure all parameters, such as power and harmonic. You can then switch pages to view the needed information immediately.




#### DMM Display

Display parameters such as voltage, current, power, power factor, and integral power in a single window.





#### Waveform Display

Display the voltage and current waveforms on channels 1 to 4 one above the other in a single window.




#### Vector Display

Display the measured value and vector of the voltage and current of each order harmonic.



#### 4-channel Waveform Display

Display the voltage and current waveforms on channels 1 to 4 individually.




#### Harmonic Bar Graph Display

Display the RMS value and phase angle of harmonics from the 0th order to the 50th either in a graph or as numerical values.


### Reliably Detect Power Supply Failures (Event)

To detect power supply failures, measurement does not need to be performed multiple times under different conditions. The PW3198 can always monitor and reliably detect all power supply failures for which detection is enabled.




#### Transient Overvoltage (Impulse)

A transient overvoltage is generated by a lightning strike or a contact fault or closed contact of a circuit breaker and relay, and often causes a steep voltage change and a high voltage peak.




#### Voltage Dip (Voltage Drop)

Voltage drops for a short time as a result of large inrush current generated in the load by, for example, a starting motor.




#### Voltage Swell (Voltage Rise)

A voltage swell is generated by a lightning strike or a heavily loaded power line being opened or closed, causing the voltage to rise instantaneously.




#### Interruption

The power supply stops instantaneously or for a short or long time because electrical power transmission is stopped as a result of a lightning strike, or because the circuit breaker is tripped by a power supply short circuit.




#### Inrush Current

A large current flows instantaneously at the moment electrical equipment, a motor, or similar devices are powered on.




#### Frequency Fluctuations

An excessive increase or decrease of the load causes the operation of a generator to become unstable, resulting in frequency fluctuations.



#### High-order Harmonic

Voltage and current waveforms are distorted by noise components generated by a semiconductor control device or the like installed in the power supply of electronic equipment.



#### Harmonic

Harmonic is generated by a semiconductor control device installed in the power supply of equipment, causing distortion of voltage and current waveforms.



#### Unbalance

An increase or decrease in the load connected to each phase of the three-phase power supply or an unbalanced operation of equipment and devices causes the load of a particular phase to become heavy so that voltage and current waveforms are distorted, voltage drops, or negative phase sequence voltage is generated.




# Simultaneous Recording of **TIME PLOT Data** and **Event Waveforms**

## TIME PLOT Data


### TIME PLOT Recording of All Parameters

The PW3198 can simultaneously record 8,000 or more parameters, such as voltage, current, power, power factor, frequency, integral power, harmonic, and flicker, at the specified recording interval. The PW3198 never fails to capture the peak because it performs calculations continuously and records the maximum, minimum, and average values within the recording interval.



Trend Recording  
(TIME PLOT Recording)

EVENT Switch windows with one touch



Harmonic Recording



Flicker and ΔV10 Recording




Integral Power Recording

## Event Waveforms


### Capture up to 55,000 Instantaneous Waveforms of Power Supply Failures

The PW3198 can record up to 1,000 instantaneous waveforms of power supply failures (up to 55,000 when repeat recording is set to ON) while performing TIME PLOT recording.




#### Event List

This list records instantaneous waveforms of power supply failures (events), such as a voltage drop or inrush current, along with the time or other information. Events are always monitored, regardless of the recording interval of the TIME PLOT recording.



#### Event Waveform

The PW3198 lets you view the instantaneous waveform (200 ms) of a power supply failure in the window.








## Analyze Recorded Data with a PC Using Application Software 9624-50 PQA-HiVIEW PRO

Use Model 9624-50 PQA-HiVIEW PRO (version 2.00 or later) with a PC to analyze the data collected by the PW3198.

### Viewer Function

Display and analyze the data recorded by the PW3198 POWER QUALITY ANALYZER.



#### Event List Window

Display a list of power supply failures (events) that occurred.

#### TIME PLOT Window

Display the TIME PLOT (recorded trend) data as well as changes in the voltage/current RMS values, harmonic, and many other parameters.

#### Event Waveform Window


Display the waveform of an event that occurred, plus the vector, harmonic, DMM, and instantaneous harmonic values.

#### ITIC Curve Display Window


Analyze the ITIC (CBEMA) curve (tolerance curve) used in the power quality standards in the United States.




Status Window



Transient Waveform Window



Inrush Current Event Graph Window




Harmonics TIME PLOT Window

### Report Creation Function

Automatically and effortlessly create rich reports for compliance and record management.

Report output items: Voltage/current RMS value fluctuation graph, harmonic fluctuation graph, inter-harmonics fluctuation graph, flicker graph, integral power graph, demand graph, total harmonic voltage/current distortion rate list, EN50160 window (Overview, Harmonic, Measurement Results Category), worst case, transient waveform, maximum/minimum value list, all event waveforms/detailed list, and setup list

#### Print Examples



RMS Value Voltage Fluctuations



All Event Detailed List



TIME PLOT Recording of Parameters



EN50160

### Other Functions

#### CSV Conversion of Measurement Data

Convert data in the range specified in the TIME PLOT window into CSV format and then save for further processing. The 9624-50 can also convert event waveforms into CSV format. Open CSV data using any commercially available spreadsheet software for advanced data management and analysis.

#### Even Analyze Data Recorded with Models 3196 and 3197 PQAs

Data recorded with the HIOKI 3196 and 3197 Power Quality Analyzers can also be analyzed.

#### Download Measurement Data via USB/LAN

Data in the SD card inserted in the PW3198 can be downloaded to a PC via USB or LAN.

#### EN50160 Display Function

EN50160 is a power quality standard for the EU. In this mode, evaluate and analyze power quality in accordance with the standard. You can display the Overview, Harmonic, and Measurement Results Category windows.

#### 9624-50 Specifications

Delivery media	CD-R
Operating environment	AT-compatible PC
OS	Windows XP, Windows Vista (32-bit), Windows 7 (32/64-bit)
Memory	512 MB or more







## Useful Functions for a Wide Variety of Applications

### Large Capacity Recording with SD Card

Data is recorded to a large capacity SD card. The data can be transferred to a PC and analyzed using dedicated application software. If your PC is not equipped with an SD card slot, simply connect a USB cable between the PW3198 and the PC. The PC will then recognize the SD card as removable media.



Repeat record	Recording period
OFF	Max. 35 days Reference value: ALL DATA (all items recorded), repeat recording OFF, and TIME PLOT interval 1 minute or longer
ON	Max. 55 weeks (about 1 year) Reference value: ALL DATA (all items recorded), repeat recording ON (1 week x 55 times), and TIME PLOT interval 10 minutes or longer

### Remote Measurement Using HTTP Server Function


You can use any Internet browser to remotely operate the PW3198, plus download the data stored in the SD card using dedicated software (LAN access required).



Conduct off-site remote control with a tablet PC using a wireless LAN router

### GPS Time Synchronization

The PW9005 GPS BOX lets you synchronize the clock on the PW3198 to the UTC standard time. Eliminate time differences between multiple PQAs and correctly analyze measurement data taken by several instruments.



### Simultaneously Measure Three-phase Lines and Grounding Wire

Apart from the main measurement line, you can also measure the AC/DC voltage on another line using Channel 4.



#### Yes! Simultaneously!

- Measure the primary and secondary sides of UPS
- Two-line voltage analysis
- Measure three-phase lines and grounding wire
- Measure neutral lines to detect short circuits
- Measure the input and output of a DC-AC converter for solar power generation




### An Assortment of Clamp-on Sensors Covers a Broad Range of Measurements

In addition to current sensors for measuring 100A AC, 500A AC, 1000A AC and 5000A AC rated currents, a 5A AC sensor is also available. In addition, HIOKI's CLAMP ON LEAK SENSORS enable you to accurately measure for leakage current down to the mA level, while the new CT969X-90 AC/DC Clamp On Sensors further widen applications by supporting DC current testing.



### Backup and Recovery from Power Failure

The PW3198 uses the new large capacity BATTERY PACK Z1003, enabling continuous measurement for three hours even if a power failure occurs. In addition, a power failure processing function restarts measurement automatically even if the power is cut off completely during measurement.



### Other Measurement Applications

#### Flicker measurement

Measure flicker in conformance with IEC 61000-4-15 Ed2.

#### Phase voltage check for $\Delta$ connection

Use the  $\Delta$ -Y and Y- $\Delta$  conversion function to measure phase voltage using a virtual neutral point.

#### 400 Hz line measurement

Measure at a power line frequency of 50/60 Hz as well as 400 Hz.



## Power Quality Survey Applications


### The power supply of the office equipment sometimes shuts down

#### Survey Objective

The power supply of a printer at the office shuts down even though it is not operated. Equipment other than the printer can also sometimes perform a reset unexpectedly.

#### Measurement Method

Setup is very easy. Just install the PW3198 on the site, and measure the voltage, current, and power. To troubleshoot, just select the clamp-on sensor and wiring, and then select the "U Events" course.



#### Analysis Report

No failure occurred during the measurement period, but a periodic voltage drop was confirmed. The voltage drop may have been caused by the periodic start and operation of the electrical equipment connected to the power supply line. Equipment, such as a laser printer, copier, and electrical heater, may start themselves periodically due to residual heat. An instantaneous voltage drop is likely to have been caused by inrush current from equipment that consumes a large amount of power.


### Medical equipment malfunctions

#### Survey Objective

Replacing the equipment with a new one by the service provider did not improve the malfunction. A survey of the power supply was required to clarify the cause.

#### Measurement Method

Select the "U Events" course in the PW3198 in the same way as with the office equipment example.



#### Analysis Report

It was determined that a voltage dip (voltage drop) occurred and impacted the operation of the equipment. If a voltage dip occurs every day on a regular basis, the probable cause is the start of a large air-conditioning unit, pump, heater, or similar equipment.

### Surveying a Solar Power Generation System

#### Survey Objective


- Maintain a solar power generation system and check its operation (verify the power quality)
- Troubleshoot (impact on the peripheral equipment, operation shutdown, etc.)

#### Measurement Method


Set up the PW3198 on the site and measure the voltage, current, and power. To survey the power quality, select the "Standard power quality measurement" course in the PRESETS menu. To measure the DC voltage, connect channel 4 to the primary side of the solar panel.



#### Connection Example



Example of Voltage Waveforms at the Time of Line Switching



Example of Determining Inflow or Outflow (Inflow of 5th and 7th Order Harmonic)

#### Analysis Report

All parameters can be recorded simultaneously with a single measurement.

- Identify changes in the output voltage of the power conditioner
- Presence or absence of the occurrence of a transient overvoltage
- Frequency fluctuation important for system interconnection
- Identify changes in the harmonic voltage and current included in the output
- Power (AC), integral power (AC), etc.



# PW3198 Specifications (Accuracy guaranteed for one year)

## Measurement items

<b>Voltage</b> measurement items (TIME PLOT Recording)	RMS voltage Frequency DC voltage Harmonic voltage (0 to 50th order) Inter-harmonic voltage (0.5 to 49.5th) Total harmonic voltage distortion factor	Waveform voltage peak Frequency (1 cycle, 10-sec) IEC Flicker (Pst, PIt) Harmonic voltage phase angle (0 to 50th) High order harmonic voltage component Voltage Unbalance factor (Zero-phase /Negative-phase)
<b>Current</b> measurement items (TIME PLOT Recording)	RMS current Waveform current peak Harmonic current phase angle (0 to 50th) Harmonic current (0 to 50th) Inter-harmonic current (0.5 to 49.5th)	High order harmonic current component Total harmonic current distortion factor Current Unbalance factor (Zero-phase /Negative-phase) K factor DC current (when using compatible sensor)
<b>Power</b> measurement items (TIME PLOT Recording)	Active power Reactive power Apparent power Power factor	Harmonic power (0 to 50th) Harmonic voltage-current phase angle (0 to 50th) Active energy Reactive energy
<b>EVENT</b> measurement items (EVENT Recording)	Transient overvoltage Voltage swell Voltage dip Interruption Inrush current	Frequency fluctuations Voltage waveform comparison Timer External events
Event detection using upper and lower thresholds available with other voltage, current and power measurement parameters (excluding Integrated power, Unbalance, Inter-harmonic, Harmonic phase angle, IEC Flicker)		

## Input specifications

Measurement circuits	Single-phase 2-wire (1P2W), single-phase 3-wire (1P3W), three-phase 3-wire (3P3W2M, 3P4W2.5E) or three-phase 4-wire (3P4W) plus one extra input channel (must be synchronized to reference channel during AC/DC measurement)																								
Fundamental frequency of measurement circuit	50Hz, 60Hz, 400Hz																								
Input channels	Voltage : 4 channels (U1 to U4), Current : 4 channels (I1 to I4)																								
Input methods	Voltage : Isolated and differential inputs (channels not isolated between U1, U2 and U3; channels isolated between U1 to U3 and U4) Current : Insulated clamp-on sensors (voltage output)																								
Input resistance	Voltage : 4MΩ ±80kΩ (differential inputs) Current : 100kΩ ±10kΩ																								
Compatible clamp sensors	Units with f.s.=0.5V output at rated current input (f.s.=0.5V recommended) Units with rate of 0.1mV/A, 1mV/A, 10mV/A, or 100mV/A																								
Measurement ranges (Ch1 to Ch4 can be configured the same way; only CH4 can be configured separately)	Voltage measurement ranges																								
	<table><tr><th>Voltage measurement items</th><th>Ranges</th></tr><tr><td>Voltage measurement</td><td>600.00V</td></tr><tr><td>Transient measurement</td><td>6.0000kV peak</td></tr></table>			Voltage measurement items	Ranges	Voltage measurement	600.00V	Transient measurement	6.0000kV peak																
	Voltage measurement items	Ranges																							
	Voltage measurement	600.00V																							
	Transient measurement	6.0000kV peak																							
	PW3198 current ranges																								
	<table><tr><th>Current sensor</th><th>Current range setting (A)</th></tr><tr><td>9660</td><td>100.00 / 50.000</td></tr><tr><td>9661</td><td>500.00 / 50.000</td></tr><tr><td>9667 (500A) *Discontinued</td><td>500.00 / 50.000</td></tr><tr><td>9667 (5kA) *Discontinued</td><td>5.0000k / 500.00</td></tr><tr><td>CT9667 (500A)</td><td>500.00 / 50.000</td></tr><tr><td>CT9667 (5kA)</td><td>5.0000k / 500.00</td></tr><tr><td>9669</td><td>1.0000k / 100.00</td></tr><tr><td>9694</td><td>50.000 / 5.0000</td></tr><tr><td>9695-02</td><td>50.000 / 5.0000</td></tr><tr><td>9695-03</td><td>100.00 / 10.000</td></tr></table>			Current sensor	Current range setting (A)	9660	100.00 / 50.000	9661	500.00 / 50.000	9667 (500A) *Discontinued	500.00 / 50.000	9667 (5kA) *Discontinued	5.0000k / 500.00	CT9667 (500A)	500.00 / 50.000	CT9667 (5kA)	5.0000k / 500.00	9669	1.0000k / 100.00	9694	50.000 / 5.0000	9695-02	50.000 / 5.0000	9695-03	100.00 / 10.000
	Current sensor	Current range setting (A)																							
	9660	100.00 / 50.000																							
	9661	500.00 / 50.000																							
9667 (500A) *Discontinued	500.00 / 50.000																								
9667 (5kA) *Discontinued	5.0000k / 500.00																								
CT9667 (500A)	500.00 / 50.000																								
CT9667 (5kA)	5.0000k / 500.00																								
9669	1.0000k / 100.00																								
9694	50.000 / 5.0000																								
9695-02	50.000 / 5.0000																								
9695-03	100.00 / 10.000																								
<table><tr><th>Current sensor</th><th>Current range setting(A)</th></tr><tr><td>CT9691 (10A)</td><td>10.000 / 5.0000</td></tr><tr><td>CT9691 (100A)</td><td>100.00 / 10.000</td></tr><tr><td>CT9692 (20A)</td><td>50.000* / 5.0000</td></tr><tr><td>CT9692 (200A)</td><td>500.00* / 50.000</td></tr><tr><td>CT9693 (200A)</td><td>500.00* / 50.000</td></tr><tr><td>CT9693 (2kA)</td><td>5.0000k* / 500.00</td></tr><tr><td>9657-10</td><td>5.0000 / 500.00m</td></tr><tr><td>9675</td><td>5.0000 / 500.00m</td></tr></table>			Current sensor	Current range setting(A)	CT9691 (10A)	10.000 / 5.0000	CT9691 (100A)	100.00 / 10.000	CT9692 (20A)	50.000* / 5.0000	CT9692 (200A)	500.00* / 50.000	CT9693 (200A)	500.00* / 50.000	CT9693 (2kA)	5.0000k* / 500.00	9657-10	5.0000 / 500.00m	9675	5.0000 / 500.00m					
Current sensor	Current range setting(A)																								
CT9691 (10A)	10.000 / 5.0000																								
CT9691 (100A)	100.00 / 10.000																								
CT9692 (20A)	50.000* / 5.0000																								
CT9692 (200A)	500.00* / 50.000																								
CT9693 (200A)	500.00* / 50.000																								
CT9693 (2kA)	5.0000k* / 500.00																								
9657-10	5.0000 / 500.00m																								
9675	5.0000 / 500.00m																								
*The full scale for each sensor is based on the specifications of the sensor in use, not the range setting on the PW3198.																									
PW3198 Power ranges (automatically configured based on current range)																									
<table><tr><th>Current range</th><th>Power range (W / VA / var)</th></tr><tr><td>5.0000 kA</td><td>3.0000M</td></tr><tr><td>1.0000 kA</td><td>600.00k</td></tr><tr><td>500.00 A</td><td>300.00k</td></tr><tr><td>100.00 A</td><td>60.000k</td></tr></table>			Current range	Power range (W / VA / var)	5.0000 kA	3.0000M	1.0000 kA	600.00k	500.00 A	300.00k	100.00 A	60.000k													
Current range	Power range (W / VA / var)																								
5.0000 kA	3.0000M																								
1.0000 kA	600.00k																								
500.00 A	300.00k																								
100.00 A	60.000k																								
<table><tr><th>Current range</th><th>Power range (W / VA / var)</th></tr><tr><td>50.000 A</td><td>30.000k</td></tr><tr><td>10.000 A</td><td>6.0000k</td></tr><tr><td>5.0000 A</td><td>3.0000k</td></tr></table>			Current range	Power range (W / VA / var)	50.000 A	30.000k	10.000 A	6.0000k	5.0000 A	3.0000k															
Current range	Power range (W / VA / var)																								
50.000 A	30.000k																								
10.000 A	6.0000k																								
5.0000 A	3.0000k																								

## Basic specifications

Maximum recording period	55 weeks (with repeated recording set to [1 Week], 55 iterations) 55 days (with repeated recording set to [1 Day], 55 iterations) 35 days (with repeated recording set to [OFF])
Maximum recordable events	55,000 events (with repeated recording on) 1000 events (with repeated recording off)
TIME PLOT data settings	TIME PLOT interval (MAX/MIN/AVG within each interval recorded) 1s, 3s, 15s, 30s, 1m, 5m, 10m, 15m, 30m, 1h, 2h, 150 cycle (at 50Hz), 180 cycle (at 60Hz), 1200 cycle (at 400Hz) Screen copy interval (screen shot at each interval saved to SD card) OFF, 5m, 10m, 30m, 1h, 2h Timer EVENT interval (200ms instantaneous waveform saved at each interval) OFF, 1m, 5m, 10m, 30m, 1h, 2h Time start and End OFF: Start recording manually ON: Start time and End time can be configured Repeated recording settings (maximum 55 iterations) OFF: Recording is not repeated 1Week: 55 weeks maximum in 1week segmentations 1Day: 55 days maximum in 1day segmentations Repeat time Daily Start time and End time can be configured when Repeated recording set to 1Day.
Recording items settings	Power (Small): Recording basic parameters P&Harm (Normal): Recording basic parameters and harmonics All Data (Full): Recording P&Harm items and inter-harmonics
Memory data capacity	Max. 32 GB with SD Card; only use of the HIOKI 2GB SD Memory Card Model Z4001 is guaranteed by HIOKI. Contact your HIOKI representative for special order larger capacity cards that offer the HIOKI guarantee.



PRESETS function	<b>U Events</b> : Record and monitor voltage elements and frequency, plus detect events <b>Standard Power Quality</b> : Record and monitor voltage and current elements, frequency, and harmonics, plus detect events <b>Inrush Current</b> : Measure inrush current (basic voltage measurement required) <b>Recording</b> : Record only trend data, no event detection <b>EN50160</b> : Measure according to EN50160 standards
Real-Time Clock function	Auto-calendar, leap-year correcting 24-hour clock
Real-time clock accuracy	$\pm 0.3$ s per day (with instrument on, $23^{\circ}\text{C} \pm 5^{\circ}\text{C}$ ( $73^{\circ}\text{F} \pm 9^{\circ}\text{F}$ ))
Power supply	<b>AC ADAPTER Z1002</b> (12 VDC, Rated power supply 100VAC to 240VAC, 1.7Amax, 50/60Hz) <b>BATTERY PACK Z1003</b> (Ni-MH 7.2VDC 4500 mAh)
Maximum rated power	15VA (when not charging), 35VA (when charging)
Continuous battery operation time	Approx. 180 min. [ $@23^{\circ}\text{C}$ ( $@73.4^{\circ}\text{F}$ ), when using <b>BATTERY PACK Z1003</b> ]
Recharge function	<b>BATTERY PACK Z1003</b> charges regardless of whether the instrument is on or off; charge time: max. 5 hr. 30 min. $@23^{\circ}\text{C}$ ( $@73.4^{\circ}\text{F}$ )
Power outage processing	In the event of a power outage during recording, instrument resumes recording once the power is back on (integral power starts from 0).
Power supply quality measurement method	IEC61000-4-30 Ed.2 :2008 IEEE1159 EN50160 (using Model <b>PQA-HiVIEW PRO 9624-50</b> )
Dimensions	Approx. 300 W x 211 H x 68 D mm (11.81" W x 8.31" H x 2.68" D) (excluding protrusions)
Mass	Approx. 2.6 kg (91.7 oz.) (including battery pack)
Accessories	Instruction manual, Measurement guide, <b>VOLTAGE CORD L1000</b> (8 cords, approx. 3 m each: 1 each red, yellow, blue, and gray plus 4 black; 8 alligator clips: 1 each red, yellow, blue, and gray plus 4 black), Spiral Tube, Input Cable Labels (for identifying channel of voltage cords and clamp-on sensors), <b>AC ADAPTER Z1002</b> , Strap, USB cable (1 m length), <b>BATTERY PACK Z1003</b> , <b>SD MEMORY CARD (2GB) Z4001</b>

### Display specifications

Display	6.5-inch TFT color LCD (640 x 480 dots)
---------	---

### External Interface Specifications

SD card Interface	Saving of binary data, Saving and Loading setting files, Saving and Loading screen copies Slot : SD standard compliant Compatible card : SD memory card/ SDHC memory card Supported memory capacity : Max: 32 GB with SD Card; only use of the HIOKI 2GB SD Memory Card Model Z4001 is guaranteed by HIOKI. <i>Contact your HIOKI representative for special order larger capacity cards that offer the HIOKI guarantee.</i> Media full processing : Saving of data to SD memory card is stopped												
RS-232C Interface	Measurement and control using GPS-synchronized time (connecting GPS BOX) Connector : D-sub9pin Connection destination : GPS box (cannot be connected to computer)												
LAN Interface	1. HTTP server function (compatible software: Internet Explorer Ver.6 or later, Remote operation application function, measurement start and stop control functions, system configuration function, event list function (capable of displaying event waveforms, event vectors, and event harmonic bar graphs) 2. Downloading of data from the SD memory card using the 9624-50 PQA-HiView Pro Connector : RJ-45 Transmission method : 10BASE-T,100BASE-TX												
USB2.0 Interface	1. Recognizes the SD memory card as a removable disk when connected to a computer. <i>The instrument cannot be connected during recording (including standby operation) or analysis.</i> 2. Download data from the SD memory card using the 9624-50 PQA-HiView Pro <i>The instrument cannot be connected during recording (including standby operation) or analysis.</i> Connector : Series B receptacle Connection destination : Computer [WindowsXP, WindowsVista(32bit), Windows7 (32/64bit)]												
External control interface	Connector : 4-pin screwless terminal block External event input : External event input at TTL low level (at falling edge of 1.0 V or less and when shorted) between GND terminal and EVENT IN terminal Min. pulse width: 30 ms; rated voltage: -0.5 V to +6.0 V External event output : <table><tr><th>External event output item setting</th><th>Operation</th><th>Pulse width</th></tr><tr><td>Short pulse output</td><td>TTL low output at event generation between [GND] terminal and [EVENT OUT] terminal</td><td>Low level for 10 ms or more</td></tr><tr><td>Long pulse output</td><td>TTL low output at event generation between [GND] terminal and [EVENT OUT] terminal (No external event output at START event)</td><td>Low level for approx. 2.5 s</td></tr><tr><td><math>\Delta V10</math> alarm</td><td>TTL low output at <math>\Delta V10</math> alarm between [GND] terminal and [EVENT OUT] terminal</td><td>Low level while alarm occurring ; reverts to high at data reset</td></tr></table>	External event output item setting	Operation	Pulse width	Short pulse output	TTL low output at event generation between [GND] terminal and [EVENT OUT] terminal	Low level for 10 ms or more	Long pulse output	TTL low output at event generation between [GND] terminal and [EVENT OUT] terminal (No external event output at START event)	Low level for approx. 2.5 s	$\Delta V10$ alarm	TTL low output at $\Delta V10$ alarm between [GND] terminal and [EVENT OUT] terminal	Low level while alarm occurring ; reverts to high at data reset
External event output item setting	Operation	Pulse width											
Short pulse output	TTL low output at event generation between [GND] terminal and [EVENT OUT] terminal	Low level for 10 ms or more											
Long pulse output	TTL low output at event generation between [GND] terminal and [EVENT OUT] terminal (No external event output at START event)	Low level for approx. 2.5 s											
$\Delta V10$ alarm	TTL low output at $\Delta V10$ alarm between [GND] terminal and [EVENT OUT] terminal	Low level while alarm occurring ; reverts to high at data reset											

### Environment and safety specifications

Operating environment	Indoors, altitude up to 3000 m (measurement category is lowered to 600 V CAT III when above 2000m), Pollution degree 2
Storage temperature and humidity	-20 to $50^{\circ}\text{C}$ (-4 to $122^{\circ}\text{F}$ ) 80% RH or less (non-condensating) (If the instrument will not be used for an extended period of time, remove the battery pack and store in a cool location [from -20 to $30^{\circ}\text{C}$ (-4 to $86^{\circ}\text{F}$ )]).
Operating temperature and humidity	0 to $50^{\circ}\text{C}$ (32 to $122^{\circ}\text{F}$ ) 80% RH or less (non-condensating)
Dust and water resistance	IP30 (EN60529)
Maximum input voltage	Voltage input section 1000 VAC, DC $\pm 600$ V, max. peak voltage $\pm 6000$ V <sub>peak</sub> Current input section 3VAC, DC $\pm 4.24$ V
Maximum rated voltage to earth	Voltage input terminal 600 V (Measurement Categories IV, anticipated transient overvoltage 8000 V)
Dielectric strength	6.88 kVrms ( $@50/60$ Hz, 1 mA sense current): Between voltage measurement terminals (U1 to U3) and voltage measurement terminals (U4) 4.30 kVrms (1 mA $@50/60$ Hz, 1 mA sense current): Between voltage input terminal (U1 to U3) and current input terminals/interfaces Between voltage (U4) and current measurement terminals, and interfaces
Applicable standards	Safety EN61010 EMC EN61326 Class A, EN61000-3-2, EN61000-3-3



**Measurement Specifications** (For specifications when measuring 400Hz circuits, please inquire with your HIOKI distributor.)

<b>TIME PLOT</b>	The MAX/MIN/AVG of each recording interval for each parameter are recorded.
<b>EVENT</b>	When a power anomaly occurs, approx. 200ms instantaneous waveform is recorded.
<b>TRANSIENT</b>	When a transient overvoltage is detected, the 2ms instantaneous waveforms before and after the occurrence (total 4ms) are recorded.
<b>FLUCTUATION</b>	The RMS fluctuation 0.5s before and 29.5s after an event has occurred are recorded.
<b>HIGH-ORDER HARM</b>	When a high order harmonic event occurs, the 40ms instantaneous waveform is recorded.

#### Transient overvoltage

**TRANSIENT**

**EVENT**

Display items	For single transient incidents and continuous transient incidents Transient voltage value, Transient width For continuous transient incidents Transient period (Period from transient IN to transient OUT) Max. transient voltage value (Max. peak value during the period) Transient count during period
Measurement method	Detected from waveform obtained by eliminating the fundamental component (50/60/400 Hz) from the sampled waveform
Sampling frequency	2MHz
Measurement range, resolution	$\pm 6.0000\text{kVpeak}$ , $0.0001\text{kV}$
Measurement bandwidth	5 kHz (-3dB) to 700 kHz (-3dB)
Min. detection width	0.5 $\mu\text{s}$
Measurement accuracy	$\pm 5.0\%$ rdg. $\pm 1.0\%$ f.s.

#### RMS voltage/ RMS current refreshed each half-cycle

**TIME PLOT**

**EVENT**

Measurement method	RMS voltage refreshed each half-cycle : True RMS type, RMS voltage values are calculated using sample data for 1 waveform derived by overlapping the voltage waveform every half-cycle RMS current refreshed each half-cycle : RMS current is calculated using current waveform data sampled every half-cycle
Sampling frequency	200kHz
Measurement range, resolution	RMS voltage refreshed each half-cycle : $600.00\text{V}$ , $0.01\text{V}$ RMS current refreshed each half-cycle : Based on clamp-on sensor in use; see Input specifications
Measurement accuracy	RMS voltage refreshed each half-cycle : $\pm 0.2\%$ of nominal voltage (With 1.666% f.s. to 110% f.s. input and a nominal input voltage of at least 100 V) $\pm 0.2\%$ rdg. $\pm 0.08\%$ f.s. (With input outside the range of 1.666% f.s. to 110% f.s. or a nominal input voltage of less than 100 V) RMS current refreshed each half-cycle : $\pm 0.3\%$ rdg. $\pm 0.5\%$ f.s. + clamp-on sensor accuracy

#### Swell/ Dip/ Interruption

**FLUCTUATION**

**EVENT**

Display item	Swell : Swell height, Swell duration Dip : Dip depth, Dip duration Interruption : Interruption depth, Interruption duration
Measurement method	Swell : A swell is detected when the RMS voltage refreshed each half-cycle exceeds the threshold in the positive direction Dip : A dip is detected when the RMS voltage refreshed each half-cycle exceeds the threshold in the negative direction Interruption : An interruption is detected when the RMS voltage refreshed each half-cycle exceeds the threshold in the negative direction
Range and accuracy	See RMS voltage refreshed each half-cycle

#### Inrush current

**FLUCTUATION**

**EVENT**

Display item	Maximum current of RMS current refreshed each 1/2 cycle
Measurement method	Detected when the RMS current refreshed each 1/2 cycle exceeds the threshold in a positive direction
Range and accuracy	See RMS current refreshed each half-cycle

#### RMS voltage, RMS current

**TIME PLOT**

**EVENT**

Display items	RMS voltage : RMS voltage for each channel and AVG (average) RMS voltage for multiple channels RMS current : RMS current for each channel and AVG (average) RMS current for multiple channels
Measurement method	AC+DC True RMS type (Current DC value: with release of new clamp-on sensor) RMS value calculated from 10 cycles (50 Hz) or 12 cycles (60 Hz)
Sampling frequency	200kHz
Measurement range, resolution	RMS voltage : $600.00\text{V}$ , $0.01\text{V}$ RMS current : Based on clamp-on sensor in use; see Input specifications
Measurement accuracy	RMS voltage : $\pm 0.1\%$ of nominal voltage (With 1.666% f.s. to 110% f.s. input and a nominal input voltage of at least 100 V) $\pm 0.2\%$ rdg. $\pm 0.08\%$ f.s. (With input outside the range of 1.666% f.s. to 110% f.s. or a nominal input voltage of less than 100 V) RMS current : $\pm 0.2\%$ rdg. $\pm 0.1\%$ f.s. + clamp-on sensor accuracy

#### Voltage waveform peak/ Current waveform peak

**TIME PLOT**

**EVENT**

Display item	Positive peak value and negative peak value
Measurement method	Measured every 10 cycles (50 Hz) or 12 cycles (60 Hz) maximum and minimum points sampled during approx. 200 ms aggregation
Sampling frequency	200kHz
Measurement range, resolution	Voltage waveform peak : $\pm 1200.0\text{Vpeak}$ , $0.1\text{V}$ Current waveform peak : The quadruple of RMS current measurement range (Based on clamp-on sensor in use; See Input specifications)

#### Voltage waveform comparison

**EVENT**

Display item	Event detection only
Measurement method	A judgment area is automatically generated from the previous 200 ms aggregation waveform, and events are generated based on a comparison with the judgment waveform. Waveform judgments are performed once for each 200 ms aggregation.
Comparison window width	10 cycles (50 Hz), 12 cycles (60 Hz)
No. of window points	4096 points synchronized with harmonic calculations

#### Frequency cycle

**TIME PLOT**

**EVENT**

Measurement method	Calculated as the reciprocal of the accumulated whole-cycle time during one U1 (reference channel) cycle
Measurement range, resolution	70.000Hz, 0.001Hz
Measurement bandwidth	40.000 to 70.000Hz
Measurement accuracy	$\pm 0.200\text{ Hz}$ or less (for input from 10% f.s. to 110% f.s.)

#### Frequency

**TIME PLOT**

**EVENT**

Measurement method	Calculated as the reciprocal of the accumulated whole-cycle time during approx. 200ms period of 10 or 12 U1 (reference channel) cycles
Measurement range, resolution	70.000Hz, 0.001Hz
Measurement bandwidth	40.000 to 70.000Hz
Measurement accuracy	$\pm 0.020\text{ Hz}$ or less

#### 10-sec frequency

**TIME PLOT**

Measurement method	Calculated as the reciprocal of the accumulated whole-cycle time during the specified 10s period for U1 (reference channel) as per IEC61000-4-30
Measurement range, resolution	70.000Hz, 0.001Hz
Measurement bandwidth	40.000 to 70.000Hz
Measurement accuracy	$\pm 0.010\text{ Hz}$ or less



**Voltage DC value (ch4 only)****TIME PLOT****EVENT**

Measurement method	Average value during approx. 20ms aggregation synchronized with the reference channel (CH4 only)
Sampling frequency	200kHz
Measurement range, resolution	600.00V, 0.01V
Measurement accuracy	$\pm 0.3\%$ rdg. $\pm 0.08\%$ f.s.

**Current DC value (ch4 only; when using compatible sensor)****TIME PLOT****EVENT**

Measurement method	Average value during approx. 200ms aggregation synchronized to reference channel (CH4 only)
Sampling frequency	200kHz
Measurement range, resolution	Based on clamp-on sensor in use (with release of new clamp-on sensor)
Measurement accuracy	$\pm 0.5\%$ rdg. $\pm 0.5\%$ f.s. + clamp-on sensor accuracy

**Active power/ Apparent power/ Reactive power****TIME PLOT****EVENT**

Display items	Active power : Active power for each channel and sum value for multiple channels. Sink (consumption) and Source (regeneration) Apparent power : Apparent power of each channel and its sum for multiple channels No polarity Reactive power : Reactive power of each channel and its sum for multiple channels Lag phase (LAG: current lags voltage) and Lead phase (LEAD: current leads voltage)
Measurement method	Active power : Measured every 10 cycles (50 Hz) or 12 cycles (60 Hz) Apparent power : Calculated from RMS voltage U and RMS current I Reactive power : Calculated using apparent power S and active power P
Sampling frequency	200kHz
Measurement range, resolution	Depends on the voltage $\times$ current range combination; see Input specifications
Measurement accuracy	Active power : $\pm 0.2\%$ rdg. $\pm 0.1\%$ f.s. + clamp-on sensor accuracy Apparent power : $\pm 1$ dgt. for calculations derived from the various measurement values Reactive power : $\pm 1$ dgt. for calculations derived from the various measurement values

**Active energy /Reactive energy****TIME PLOT**

Display items	Active energy : WP+ (consumption), WP- (regeneration); Sum of multiple channels Reactive energy : WQLAG (lag), WQLEAD (lead); Sum for multiple channels Elapsed time
Measurement method	Measured every 10 cycles (50 Hz) or 12 cycles (60 Hz) Integrated separately by consumption and regeneration from active power Integrated separately by lag and lead from reactive power Integration starts at the same time as recording Recorded at the specified TIMEPLOT interval
Sampling frequency	200kHz
Measurement range, resolution	Depends on the voltage $\times$ current range combination; see Input specifications
Measurement accuracy	Active energy : Active power measurement accuracy $\pm 10$ dgt. Reactive energy : Reactive power measurement accuracy $\pm 10$ dgt.

**Power factor /Displacement power factor****TIME PLOT****EVENT**

Display items	Displacement power factor of each channel and its sum value for multiple channels
Measurement method	Power factor : Calculated from RMS voltage U, RMS current I, and active power P Displacement power factor : Calculated from the phase difference between the fundamental voltage wave and the fundamental current wave Lag phase (LAG: current lags voltage) and Lead phase (LEAD: current leads voltage)
Sampling frequency	200kHz
Measurement range, resolution	-1.0000 (lead) to 0.0000 to 1.0000 (lag)

**Voltage unbalance factor/ Current unbalance factor (negative-phase, zero-phase)****TIME PLOT**

Display items	Voltage unbalance factor : Negative-phase unbalance factor, zero-phase unbalance factor Current unbalance factor : Negative-phase unbalance factor, zero-phase unbalance factor
Measurement method	Calculated using various components of the three-phase fundamental wave (line-to-line voltage) for three-phase 3-wire (3P3W2M, 3P3W3M) and three-phase 4-wire connections
Sampling frequency	200kHz
Measurement range	Voltage unbalance factor : Component is V and unbalance factor is 0.00% to 100.00% Current unbalance factor : Component is V and unbalance factor is 0.00% to 100.00%
Measurement accuracy	Voltage unbalance factor : $\pm 0.15\%$ Current unbalance factor : —

**High-order harmonic voltage component/ High-order harmonic current component****HIGH-ORDER HARM****TIME PLOT****EVENT**

Display items	For single incidents and continuous transient incidents High-order harmonic voltage component value High-order harmonic current component value For continuous incidents High-order harmonic voltage component maximum value High-order harmonic current component maximum value High-order harmonic voltage component period High-order harmonic current component period
Measurement method	The waveform obtained by eliminating the fundamental component is calculated using the true RMS method during 10 cycles (50 Hz) or 12 cycles (60 Hz) of the fundamental wave
Sampling frequency	200kHz
Measurement range, resolution	High-order harmonic voltage component : 600.00V, 0.01V High-order harmonic current component : Based on clamp-on sensor in use; See Input specifications
Measurement bandwidth	2kHz (-3dB) to 80kHz (-3dB)
Measurement accuracy	High-order harmonic voltage component : $\pm 10\%$ rdg. $\pm 0.1\%$ f.s. High-order harmonic current component : $\pm 10\%$ rdg. $\pm 0.2\%$ f.s. + clamp-on sensor accuracy

**Harmonic voltage/ Harmonic current (including fundamental component)****TIME PLOT****EVENT**

Display items	Select either RMS or content percentage; From 0 to 50th order
Measurement method	Uses IEC61000-4-7:2002.
Comparison window width	10 cycles (50 Hz), 12 cycles (60 Hz)
No. of window points	4096 points synchronized with harmonic calculations
Measurement range, resolution	Harmonic voltage : 600.00V, 0.01V Harmonic current : Based on clamp-on sensor in use; see Input specifications
Measurement accuracy	See measurement accuracy with a fundamental wave of 50/60 Hz When using an AC-only clamp sensor, 0th order is not specified for current and power



**Total harmonic voltage/ Total harmonic current distortion factor****TIME PLOT****EVENT**

Display items	THD-F (total harmonic distortion factor for the fundamental wave) THD-R (total harmonic distortion factor for the total harmonic including the fundamental wave)
Measurement method	Based on IEC61000-4-7:2002; Max. order: 50th
Comparison window width	10 cycles (50 Hz), 12 cycles (60 Hz)
No. of window points	4096 points synchronized with harmonic calculations
Measurement range, resolution	0.00 to 100.00%(Voltage), 0.00 to 500.00%(Current)
Measurement accuracy	—

**Harmonic power (including fundamental component)****TIME PLOT****EVENT**

Display item	Select either RMS or content percentage; From 0 to 50th order
Measurement method	Uses IEC61000-4-7:2002.
Comparison window width	10 cycles (50 Hz), 12 cycles (60 Hz)
No. of window points	4096 points synchronized with harmonic calculations
Measurement range, resolution	Depends on the voltage × current range combination; See Input specifications
Measurement accuracy	See measurement accuracy with a fundamental wave of 50/60 Hz (When using an AC-only clamp sensor, order 0 is not specified for current and power)

Measurement accuracy with a fundamental wave of 50/60 Hz

Harmonic input	Measurement accuracy
Voltage (At least 1% of nominal voltage)	Specified with a nominal voltage of at least 100 V Order 0: ±0.3%rdg.±0.08%f.s. Order 1+: ±5.00%rdg
Voltage (<1% of nominal voltage)	Specified with a nominal voltage of at least 100 V Order 0: ±0.3%rdg.±0.08%f.s. Order 1+: ±0.05% of nominal voltage
Current	Order 0: ±0.5%rdg.±0.5%f.s. +clamp-on sensor accuracy Order 1 to 20th: ±0.5%rdg.±0.2%f.s. +clamp-on sensor accuracy Order 21 to 50th: ±1.0%rdg.±0.3%f.s. +clamp-on sensor accuracy
Power	Order 0: ±0.5%rdg.±0.5%f.s. +clamp-on sensor accuracy Order 1 to 20th: ±0.5%rdg.±0.2%f.s. +clamp-on sensor accuracy Order 21 to 30th: ±1.0%rdg.±0.3%f.s. +clamp-on sensor accuracy Order 31 to 40th: ±2.0%rdg.±0.3%f.s. +clamp-on sensor accuracy Order 41 to 50th: ±3.0%rdg.±0.3%f.s. +clamp-on sensor accuracy

**Harmonic voltage phase angle/ Harmonic current phase angle (including fundamental component)****TIME PLOT**

Display item	Harmonic phase angle components for whole orders
Measurement method	Uses IEC61000-4-7:2002.
Comparison window width	10 cycles (50 Hz), 12 cycles (60 Hz)
No. of window points	4096 points synchronized with harmonic calculations
Measurement range, resolution	-180.00° to 0.00° to 180.00°
Measurement accuracy	—

**Harmonic voltage-current phase angle (including fundamental component)****TIME PLOT****EVENT**

Display item	Indicates the difference between the harmonic voltage phase angle and the harmonic current phase angle. Harmonic voltage-current phase difference for each channel and sum (total) value for multiple channels
Measurement method	Uses IEC61000-4-7:2002.
Comparison window width	10 cycles (50 Hz), 12 cycles (60 Hz)
No. of window points	4096 points synchronized with harmonic calculations
Measurement range, resolution	-180.00° to 0.00° to 180.00°
Measurement accuracy	1st to 3rd orders : ± 2° + clamp-on sensor accuracy 4th to 50th orders: ±(0.05° × k+2°) + clamp-on sensor accuracy; (k: harmonic orders) Specified with a harmonic voltage of 1 V for each order and a current level of at 1% f.s. or greater.

**Inter-harmonic voltage and inter-harmonic current****TIME PLOT**

Display item	Select either RMS or content percentage; 0.5 to 49.5th orders
Measurement method	Uses IEC61000-4-7:2002.
Comparison window width	10 cycles (50 Hz), 12 cycles (60 Hz)
No. of window points	4096 points synchronized with harmonic calculations
Measurement range, resolution	Inter-harmonic voltage : 600.00V, 0.01V Inter-harmonic current : Due to using clamp-on sensor; See Input specifications
Measurement accuracy	Inter-harmonic voltage (Specified with a nominal voltage of at least 100 V): At least 1% of harmonic input nominal voltage; ±5.00% rdg. <1% of harmonic input nominal voltage : ±0.05% of nominal voltage Inter-harmonic current : Unspecified

**K Factor (multiplication factor)****TIME PLOT****EVENT**

Measurement method	Calculated using the harmonic RMS current of the 2nd to 50th orders
Comparison window width	10 cycles (50 Hz), 12 cycles (60 Hz)
No. of window points	4096 points synchronized with harmonic calculations
Measurement range, resolution	0.00 to 500.00
Measurement accuracy	—

**Instantaneous flicker value****TIME PLOT**

Measurement method	As per IEC61000-4-15 User-selectable from 230 Vlamp/120 Vlamp (when Pst and Plt are selected for flicker measurement)/4 types of Ed2 filter (230 Vlamp 50/60 Hz, 120 Vlamp 60/50 Hz)
Measurement range, resolution	99.999, 0.001

**Δ V10 Flicker****TIME PLOT**

Display items	ΔV10 measured at one minute intervals, average value for one hour, maximum value for one hour, fourth largest value for one hour, total (within the measurement interval) maximum value
Measurement method	Calculated values are subject to 100 V conversion following gap-less measurement once each minute
Measurement range, resolution	0.000 to 99.999V
Measurement accuracy	±2% rdg.±0.01 V (with a fundamental wave of 100 Vrms [50/60 Hz], a fluctuation voltage of 1 Vrms, and a fluctuation frequency of 10 Hz)
Threshold	0.00 to 9.99V alarm output is generated when the reading for each minute is compared to the threshold and found to be greater

**IEC Flicker****TIME PLOT**

Display items	Short interval flicker Pst, long interval flicker Plt
Measurement method	Based on IEC61000-4-15:1997 +A1:2003 Ed1/Ed2. Pst is calculated after 10 minutes of continuous measurement and Plt after 2 hours of continuous measurement
Measurement range	0.0001 to 10000 P.U. broken into 1,024 segments with a logarithm
Measurement accuracy	Pst ±5% rdg. (Specified within range 0.1000 to 20.000 using IEC61000-4-15 Ed1.1 and IEC61000-4-15 Ed2 Class F1 performance test.)
Flicker filter	Select 230 V lamp Ed1, 120 V lamp Ed1, 230 V lamp Ed2, or 120 V lamp Ed2.





## Clamp-on sensors specifications (Options)

Clamp-on sensor	CLAMP ON SENSOR 9664	CLAMP ON SENSOR 9660	CLAMP ON SENSOR 9661
Appearance			
Primary current rating	5A AC	100A AC	500A AC
Output voltage	10mV/A AC	AC 1mV/A AC	AC 1mV/A AC
Measurement range	See input specifications		
Amplitude accuracy *	$\pm 0.3\% \text{rdg} \pm 0.02\% \text{f.s.}^*$	$\pm 0.3\% \text{rdg} \pm 0.02\% \text{f.s.}^*$	$\pm 0.3\% \text{rdg} \pm 0.01\% \text{f.s.}^*$
Phase accuracy *	$\pm 2^\circ$ or less *	$\pm 1^\circ$ or less *	$\pm 0.5^\circ$ or less *
Maximum allowable input *	50 A continuous *	130 A continuous *	550 A continuous *
Maximum rated voltage to earth	CAT III 300Vrms		CAT III 600 Vrms
Frequency characteristics	$\pm 1.0\%$ or less for 65Hz to 5kHz (deviation from specified accuracy)		
Cord length	3m (9.84ft)		
Measurable conductor diameter	Max. $\phi 15\text{mm}$ (0.59")		Max. $\phi 46\text{mm}$ (1.81")
Dimensions, Mass	45W(1.81") $\times$ 135H(5.31") $\times$ 21D(0.83")mm, 230g(8.1oz.)		78W(3.07") $\times$ 152H(5.98") $\times$ 42D(1.65")mm, 380g(13.4oz.)

\*: 45 to 55Hz

Clamp-on sensor	CLAMP ON SENSOR 9669	FLEXIBLE CLAMP ON SENSOR CT9667
Appearance		
Primary current rating	1000 A AC	500A AC, 5000A AC
Output voltage	0.5mV/A AC	500 mV AC f.s.
Measurement range	See input specifications	
Amplitude accuracy *	$\pm 1.0\% \text{rdg} \pm 0.01\% \text{f.s.}^*$	$\pm 2.0\% \text{rdg} \pm 0.3\% \text{f.s.}^*$
Phase accuracy *	$\pm 1^\circ$ or less *	$\pm 1^\circ$ or less *
Maximum allowable input *	1000 A continuous *	10000 A continuous *
Maximum rated voltage to earth	CAT III 600Vrms	CAT III 1000 Vrms CAT IV 600 Vrms
Frequency characteristics	Within $\pm 2\%$ at 40Hz to 5kHz (deviation from accuracy)	$\pm 3\text{dB}$ or less for 10 Hz to 20kHz (within $\pm 3\text{dB}$ )
Cord length	3m (9.84ft)	Sensor to circuit: 2m (6.56ft) Circuit to connector: 1m (3.28ft)
Measurable conductor diameter	Max. $\phi 56\text{mm}$ (2.17"), 80 (3.15") $\times$ 20 (0.79") mm busbar	Max. $\phi 254\text{mm}$ (10")
Dimensions, Mass	99.5W (3.92") $\times$ 188H (7.40") $\times$ 42D (1.65") mm, 590g (20.8 oz.)	Circuit box: 35W (1.38") $\times$ 120.5H (4.74") $\times$ 34D (1.34") mm, 140 g (4.9 oz.)
Power supply	—	LR6 alkaline battery x2, AC Adapter (option) or external 5 to 15 V DC power supply
Options (sold separately)		AC ADAPTER 9445-02 (universal 100 to 240VAC, 9W/1A output for USA) AC ADAPTER 9445-03 (universal 100 to 240VAC, 9W/1A output for Europe)

\*: 45 to 55Hz

Clamp-on sensor	CLAMP ON SENSOR 9695-02	CLAMP ON SENSOR 9695-03
Appearance		
Primary current rating	50A AC	100A AC
Output voltage	10mV/A AC	1mV/A AC
Measurement range	See input specifications	
Amplitude accuracy *	$\pm 0.3\% \text{rdg} \pm 0.02\% \text{f.s.}^*$	$\pm 0.3\% \text{rdg} \pm 0.02\% \text{f.s.}^*$
Phase accuracy *	Within $\pm 2^\circ$ *	Within $\pm 1^\circ$ *
Maximum allowable input *	130 A continuous *	130 A continuous *
Maximum rated voltage to earth	CAT III 300Vrms (insulated conductor)	
Frequency characteristic	Within $\pm 2\%$ at 40Hz to 5kHz (deviation from accuracy)	
Cord length	CONNECTION CORD 9219 (sold separately) is required.	
Measurable conductor diameter	Max. $\phi 15\text{mm}$ (0.59")	
Dimensions, Mass	51W(2.01") $\times$ 58H(2.28") $\times$ 19D(0.75")mm, 50g(1.8oz.)	
Options (sold separately)	CONNECTION CORD 9219 (Cord length: 3m (9.84ft))	

Note: CONNECTION CORD 9219 (sold separately) is required.

\*: 45 to 55Hz



CONNECTION CORD 9219

Clamp-on AC/DC sensor	AC/DC CLAMP ON SENSOR RCT9691-90 (CT9691 bundled with the CT6590)	AC/DC CLAMP ON SENSOR RCT9692-90 (CT9692 bundled with the CT6590)	AC/DC CLAMP ON SENSOR RCT9693-90 (CT9693 bundled with the CT6590)
Appearance			
Includes	CT9691 x1, CT6590 x1	CT9692 x1, CT6590 x1	CT9693 x1, CT6590 x1
CT9691, CT9692, CT9693 (Clamp sensor) specifications			
	CT9691 	CT9692 	CT9693 
Primary current rating	100A AC/DC	200A AC/DC	2000A AC/DC
Maximum input range (RMS value)	100A rms continuous*	200A rms continuous*	2000A rms continuous*
Maximum rated voltage to earth	CAT III AC/DC 600V		
Frequency band	DC to 10 kHz (-3dB)	DC to 20 kHz (-3dB)	DC to 15 kHz (-3dB)
Cord length	2m (6.5 ft)		
Measurable conductor diameter	35 mm (1.38") or less	33 mm (1.30") or less	55 mm (2.17") or less
Dimensions, Mass	63W(2.09") x 129H(5.08") x 18D(0.71") mm, 230g (8.1 oz.)	62W(2.44") x 157H(5.57") x 38D(1.38") mm, 410g (14.5 oz.)	62W(2.44") x 195H(7.72") x 35D(1.38") mm, 500g (17.6 oz.)
CT6590 (SENSOR UNIT) specifications			
	CT6590 		
Range when combined with sensor (H/L selectable)	H range : 100A AC/DC f.s. L range : 10A AC/DC f.s.	H range : 200A AC/DC f.s. L range : 20A AC/DC f.s.	H range : 2000A AC/DC f.s. L range : 200A AC/DC f.s.
Sensor combination Output rate	H range : 1mV/A L range : 10mV/A	H range : 1mV/A L range : 10mV/A	H range : 0.1mV/A L range : 1mV/A
Sensor combination measurement range	See input specifications		
Sensor combination accuracy (Continuous input)	$\pm 1.5\% \text{rdg} \pm 1.0\% \text{f.s. (DC} \leq 1 \leq 66 \text{ Hz)}$	$\pm 1.5\% \text{rdg} \pm 0.5\% \text{f.s. (DC} \leq 1 \leq 66 \text{ Hz)}$	$\pm 2.0\% \text{rdg} \pm 0.5\% \text{f.s. (DC)}$ $\pm 1.5\% \text{rdg} \pm 0.5\% \text{f.s. (45} \leq 1 \leq 66 \text{ Hz, 1} \leq 1800 \text{ A)}$ $\pm 2.5\% \text{rdg} \pm 0.5\% \text{f.s. (45} \leq 1 \leq 66 \text{ Hz, 1800 A} \leq 2000 \text{ A)}$
Sensor combination accuracy (Phase)	$\pm 2 \text{deg. (DC} < 1 \leq 66 \text{ Hz)}$	$\pm 2 \text{deg. (DC} < 1 \leq 66 \text{ Hz)}$	$\pm 2 \text{deg. (45 Hz} \leq 1 \leq 66 \text{ Hz)}$
Cord length	1m (3.3 ft)		
Dimensions, Mass	36W(1.42") x 120H(4.72") x 34D(1.34") mm (excluding protruding parts), 165g(5.8 oz.) (including batteries)		
Power supply	LR6 alkaline battery x2, optional AC adapter, or 5 V to 15 VDC external power		
Options (sold separately)	AC ADAPTER 9445-02 (universal 100 to 240VAC, 9V/1A output for USA) AC ADAPTER 9445-03 (universal 100 to 240VAC, 9V/1A output for Europe)		

\*: Derating according to frequency.

Clamp-on leak sensor	CLAMP ON LEAK SENSOR 9657-10	CLAMP ON LEAK SENSOR 9675
Appearance		
Primary current rating	10A AC (Up to 5A on Model PW3198)	
Output voltage	100 mV/A AC	
Measurement range	See input specifications (Cannot be used to measure power)	
Amplitude accuracy*	$\pm 1.0\% \text{rdg} \pm 0.05\% \text{f.s.}^*$	$\pm 1.0\% \text{rdg} \pm 0.005\% \text{f.s.}^*$
Residual current characteristics	Max. 5mA (in 100A go and return electric wire)	Max. 1mA (in 10A go and return electric wire)
Effect of external magnetic fields	400A AC/m corresponds to 5mA, Max. 7.5mA	
Maximum rated voltage to earth	CAT III 300Vrms (insulated conductor)	
Cord length	3m (9.84 ft)	
Measurable conductor diameter	Max. $\phi 40 \text{ mm (1.57")}$	Max. $\phi 30 \text{ mm (1.18 oz.)}$
Dimensions, Mass	74W(2.91") x 145H(5.71") x 42D(1.65") mm, 380g(13.4 oz.)	60W(2.36") x 112.5H(4.43") x 23.5D(23.6") mm, 160g(5.6 oz.)

\*: 45 to 66 Hz



**Current measurement** (see P14-15 Clamp-on sensor specifications for details)

**CLAMP ON SENSOR (Load current, AC)**

9694 5A AC,  $\phi 15\text{mm}$  (0.59")

9661 500A AC,  $\phi 45\text{mm}$  (1.81")

CT9667 500A AC / 5000A AC (selectable),  $\phi 254\text{mm}$  (10"), Power supply: LR6 alkaline battery or AC ADAPTER 9445-02/03 (sold separately)

9660 100A AC,  $\phi 15\text{mm}$  (0.59")

9669 1000A AC,  $\phi 85\text{mm}$  (2.17"), 80(3.15") x 20(0.79") mm busbar

**CLAMP ON ADAPTER**

9695-02 (50A AC)  
9695-03 (100A AC)  
 $\phi 15\text{mm}$  (0.59"), CONNECTION CORD 9219 is required (sold separately)

CONNECTION CORD 9219  
For connecting 9695-02/9695-03  
Cord length: 3m (9.84ft)

9290-10 CT ratio 10:1, AC1000A,  $\phi 85\text{mm}$  (2.17"), 80(3.15") x 20(0.79") mm busbar, Cord length: 3m (9.84ft)

**CLAMP ON AC/DC SENSOR (Load current, AC/DC)**

CT9691-90 100A AC/DC / 10A AC/DC (selectable),  $\phi 35\text{mm}$  (1.38")

CT9692-90 200A AC/DC / 20A AC/DC (selectable),  $\phi 35\text{mm}$  (1.38")

CT9693-90 2000A AC/DC / 200A AC/DC (selectable),  $\phi 85\text{mm}$  (2.17")

Power supply: LR6 alkaline battery or AC ADAPTER 9445-02/03 (sold separately)

The CT9691-90, CT9692-90, and CT9693-90 represent the respective clamp sensor bundled with the CT6990 Sensor Unit.

**CLAMP ON LEAK SENSOR (Leak Current)**  
Cannot be used to measure power

9657-10 10A AC (Up to 5A on Model PW3198),  $\phi 40\text{mm}$  (1.57")

9675 10A AC (Up to 5A on Model PW3198),  $\phi 30\text{mm}$  (1.18")

**Voltage measurement**

WIRING ADAPTER PW9000 For 3P3W WIRING

WIRING ADAPTER PW9001 For 3P4W WIRING

Reduce voltage cords for easy wiring

MAGNETIC ADAPTER 9804-01 (red)  
MAGNETIC ADAPTER 9804-02 (black)  
Magnetic tip for use with the standard Voltage Cord L1000 (generally compatible with M5 pan screws)

Red and black adapters sold separately. Purchase the quantity and color appropriate for your application. (Example: 3P3W - 3 adapters; 3P4W - 4 adapters)

GRABBER CLIP 9243 For use with the standard Voltage Cord L1000

**Application software**

PQA-HVIEW PRO 9624-50  
Use Model 9624-50 PQA-HVIEW PRO (version 2.00 or later) with a PC to analyze the data collected by the PW3198.

**Case**

CARRYING CASE C1001 Soft case 450W x 345W x 210Dmm (17.7" x 13.6" x 8.3") 3.4kg (201oz.)

CARRYING CASE C1002 Hard case 413W x 395W x 265Dmm (16.3" x 23.4" x 10.4") 5.7kg (201oz.)

**Check synchronization**

GPS BOX PW9005 To synchronize the PW3198 clock. Accessory: Connection cable set

**Power Quality Analyzer PW3198-90**  
(Set with PQA-HVIEW PRO 9624-50 and bundled accessories)

**IMPORTANT**  
Use Model PQA-HVIEW PRO 9624-50 (version 2.00 or later) with a PC to analyze the data collected by the PW3198.

**Bundled accessories**

Voltage Cord L1000 8 cords, approx. 3m each: 1 each red, yellow, blue, and gray plus 4 black; 8 alligator clips: 1 each red, yellow, blue, and gray plus 4 black

AC ADAPTER Z1002 Power supply for the PW3198 100V AC to 240V AC

SD MEMORY CARD 2GB Z4001

BATTERY PACK Z1003 (Ni-MH, 7.2V/4500mAh)

**IMPORTANT**  
Use only the SD Card Z4001 sold by HIOKI.

● Combination example: For three-phase 4-wire circuits containing leak current

PW3198-90 + 9661 x 3 + 9675 + PW9001 + C1001  
POWER QUALITY ANALYZER CLAMP ON SENSOR (500A) CLAMP ON LEAK SENSOR WIRING ADAPTER CARRYING CASE  
PW3198 set with PQA-HVIEW PRO 9624-50

Note: Company names and Product names appearing in this catalog are trademarks or registered trademarks of various companies.

**HIOKI**

**HIOKI E.E. CORPORATION**

Headquarters:  
81 Koizumi, Ueda, Nagano, 386-1192, Japan  
TEL +81-268-28-0562 FAX +81-268-28-0568  
http://www.hioki.co.jp / E-mail: os-ccm@hioki.co.jp

HIOKI USA CORPORATION:  
TEL +1-609-409-9109 FAX +1-609-409-9108  
http://www.hiokiusa.com / E-mail: hioki@hiokiusa.com

HIOKI (Shanghai) Sales & Trading Co., Ltd.:  
TEL +86-21-63910090 FAX +86-21-63910060  
http://www.hioki.cn / E-mail: info@hioki.com.cn  
Beijing Office: TEL +86-10-84418781  
FAX +86-10-84418753 / E-mail: info-bj@hioki.com.cn  
Guangzhou Office: TEL +86-20-38392673  
FAX +86-20-38392679 / E-mail: info-gz@hioki.com.cn  
Shenzhen Office: TEL +86-755-83038357  
FAX +86-755-83039160 / E-mail: info-sz@hioki.com.cn  
HIOKI INDIA PRIVATE LIMITED:  
TEL +91-731-6548081 FAX +91-731-4020085  
E-mail: info@hioki.in  
HIOKI SINGAPORE PTE. LTD.:  
TEL +65-6534-7677 FAX +65-6534-7477  
E-mail: info@hioki.com.sg

DISTRIBUTED BY

## APPENDIX B PQ Logging Data for 2015/2016 FY

Please refer to the following pages.



TC1 – Flicker, Voltage and Frequency




Figure 11 | TC1 - start of feeder – flicker measurements (Red Phase)




Figure 12 | TC1 - start of feeder – voltage measurements (Red Phase)




Figure 13 | TC1 - start of feeder – frequency measurements




Figure 14 | TC1 end of feeder - flicker measurements (Red Phase)




Figure 15 | TC1 - end of feeder – voltage measurements (Red Phase)




Figure 16 | TC1 - end of feeder – frequency measurements

TC1 – Harmonics




Figure 17 | TC1 – start of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 21 | TC1 – end of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 18 | TC1 – start of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 22 | TC1 – end of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 19 | TC1 – start of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 23 | TC1 – end of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 20 | TC1 – start of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics




Figure 24 | TC1 – end of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics

TC2 – Flicker, Voltage and Frequency




Figure 25 | TC2 – end of feeder – flicker measurements (Red Phase)




Figure 26 | TC2 - end of feeder – voltage measurements (Red Phase)




Figure 27 | TC2 - end of feeder – frequency measurements

TC2 – Harmonics




Figure 28 | TC2 – end of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 29 | TC2 – end of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 30 | TC2 – end of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 31 | TC2 – end of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics

TC3 – Flicker, Voltage and Frequency




Figure 32 | TC3 - start of feeder – flicker measurements (Red Phase)




Figure 33 | TC3 - start of feeder – voltage measurements (Red Phase)




Figure 34 | TC3 - start of feeder – frequency measurements




Figure 35 | TC3 - end of feeder – flicker measurements (Red Phase)




Figure 36 | TC3 - end of feeder – voltage measurements (Red Phase)




Figure 37 | TC3 - end of feeder – frequency measurements



TC3 – Harmonics




Figure 38 | TC3 – start of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 39 | TC3 – start of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 40 | TC3 – start of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 41 | TC3 – start of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics




Figure 42 | TC3 – end of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 43 | TC3 – end of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 44 | TC3 – end of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 45 | TC3 – end of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics

TC4 – Flicker, Voltage and Frequency




Figure 46 | TC4 - start of feeder – flicker measurements (Blue Phase)




Figure 47 | TC4 - start of feeder – voltage measurements (Red Phase)




Figure 48 | TC4 - start of feeder – frequency measurements

TC4 – Harmonics




Figure 49 | TC4 – start of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 50 | TC4 – start of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 51 | TC4 – start of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 52 | TC4 – start of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics



STS1 – Flicker, Voltage and Frequency




Figure 53 | STS1 - start of feeder – flicker measurements (Red Phase)




Figure 54 | STS1 - start of feeder – voltage measurements (Red Phase)




Figure 55 | STS1 - start of feeder – frequency measurements (Red Phase)




Figure 56 | STS1 - end of feeder – flicker measurements (White Phase)




Figure 57 | STS1 - end of feeder – voltage measurements (Red Phase)




Figure 58 | STS1 - end of feeder – frequency measurements

STS1 – Harmonics




Figure 59 | STS1 - start of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 60 | STS1 – start of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 61 | STS1 – start of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 62 | STS1 – start of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics




Figure 63 | STS1 - end of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 64 | STS1 – end of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 65 | STS1 – end of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 66 | STS1 – end of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics

STS2 – Flicker, Voltage and Frequency




Figure 67 | STS2 - start of feeder – flicker measurements (Red Phase)




Figure 68 | STS2 - start of feeder – voltage measurements (Red Phase)




Figure 69 | STS2 - start of feeder – frequency measurements




Figure 70 | STS2 - end of feeder – flicker measurements (White Phase)




Figure 71 | STS2 - end of feeder – voltage measurements (Red Phase)




Figure 72 | STS2 - end of feeder – frequency measurements

STS2 – Harmonics




Figure 73 | STS2 - start of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 74 | STS2 – start of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 75 | STS2 – start of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 76 | STS2 – start of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics




Figure 77 | STS2 - end of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 78 | STS2 – end of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 79 | STS2 – end of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 80 | STS2 – end of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics



STS6 – Flicker, Voltage and Frequency




Figure 81 | STS6 - start of feeder – flicker measurements (Red Phase)




Figure 82 | STS6 - start of feeder – voltage measurements (Red Phase)




Figure 83 | STS6 - start of feeder – frequency measurements




Figure 84 | STS6 - end of feeder – flicker measurements (Blue Phase)




Figure 85 | STS6 - end of feeder – voltage measurements (Red Phase)



Figure 86 | STS6 - end of feeder – frequency measurements

STS6 – Harmonics




Figure 87 | STS6 – start of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 88 | STS6 – start of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 89 | STS6 – start of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 90 | STS6 – start of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics




Figure 91 | STS6 – end of feeder – 3<sup>rd</sup> to 13<sup>th</sup> (odd) harmonics




Figure 92 | STS6 – end of feeder – 15<sup>th</sup> to 25<sup>th</sup> (odd) harmonics




Figure 93 | STS6 – end of feeder – 2<sup>th</sup> to 12<sup>th</sup> (even) harmonics




Figure 94 | STS6 – end of feeder – 14<sup>th</sup> to 24<sup>th</sup> (even) harmonics

## APPENDIX C PQ Device Installation Checklist

Please refer to the following pages.



1/14  
PS 108  
201447



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor		Name	JULIAN PRINCEHORN	
Logger Serial No.	201447			
Site Location	PS108			
Transformer/Feeder being Logged				
Transformer Tap Setting				
Date and Time Logging Started	30/3 9:00	Date and Time Logging Completed	7/4/16 14:34	
Photo Id#	_____ (Photo after fully installed)			

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes: a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.

## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....  
.....  
.....



PS 69

2/14

201446



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor	Name		Joe Sivak
Logger Serial No.	201446		
Site Location	PS 69 Giles Ave		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time Logging Started	30/3/16	Date and Time Logging Completed	8/4/16 8:15 am
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes: a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.

## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....



3/14  
2018

PS 120 Seasons Hotel



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor	Name			JOE SWAK
Logger Serial No.	201081			
Site Location	PS 120 Season's Hotel			
Transformer/Feeder being Logged				
Transformer Tap Setting				
Date and Time Logging Started	31/3/16 1440	Date and Time Logging Completed	8/4/16 10:00 AM	
Photo Id#	_____ (Photo after fully installed)			

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes: a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.

## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....



4/14  
201448

Tx 12000 Exploration



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor		Name	Joe Snak
Logger Serial No.	201448		
Site Location	Tx 1200 Exploration		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time	31/3/16	Date and Time	8/4/16
Logging Started	1730	Logging Completed	11:45 am
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes: a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.

## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....

6/14

PE00018

PS 14 Bordini



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**



## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor		Name	Joe Swak
Logger Serial No.	PE 00018		
Site Location	PS 14 Bandini		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time Logging Started	31/3/16	Date and Time Logging Completed	8/4/16
	7:41 am		10:55 am
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes:			
	a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.



## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....

7/14

201945

PS 125 Bobbacurry loop



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor	Name		JOE SWAK
Logger Serial No.	201445		
Site Location	PS 125 Bubbacurry loop		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time Logging Started	31/3/16 8:20am	Date and Time Logging Completed	7/4/16 14:50
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).



## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....

PS 86

Red Sands

9/14

201082



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor		Name	Joe Sivak
Logger Serial No.	201 082		
Site Location	PS 86 Red Sands		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time Logging Started	31/3/16 11:50	Date and Time Logging Completed	7/6/16 14:21
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).



## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes: a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.

## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....



PS 68 Cappy Oval

10/14  
Serial No.  
1502 15780



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor	Name		JOE SIVAK
Logger Serial No.	none found		
Site Location	PS 68 Cappy oval		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time Logging Started	31/3/16 1300	Date and Time Logging Completed	8/4/16 10:20am
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes: a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.

## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....

202054

11/14

PS 70



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**



## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor	Name		Joe Swale
Logger Serial No.	202054		
Site Location	PS TO Jabber up		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time	30/3/16	Date and Time	7/4/16
Logging Started	11:40am	Logging Completed	12:22 PM
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<b><u>Safety Note:</u></b> The power board is to only supply the loggers			
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes:			
	a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.



## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....

PS 60 Forrest  
201819

12/14



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor	Name Joe Swale		
Logger Serial No.	201819		
Site Location	PS60 Forrest		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time Logging Started	30/3/16 1325	Date and Time Logging Completed	7/4/16 12:55 PM
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).



## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes:			
	a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.

## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....



201444

13/14

PS 96



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**

## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor		Name	Joe Sivak
Logger Serial No.	201 444		
Site Location	PS 96 Pardoo St		
Transformer/Feeder being Logged	PS 96		
Transformer Tap Setting			
Date and Time Logging Started	30/3/16 1340	Date and Time Logging Completed	7/4/16 10:54
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<b>Ensure the following parts are available, checked and prepared</b>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes: a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.

## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....

201981

14/14

PS 94



# BHPBIO NEWMAN COMPLIANCE & AUDIT REPORT 2015/2016

## PQ LOGGER INSTALLATION CHECKLIST

REVISION K

3/03/2016

Project No.: W\_APD04607

**APD**



## 1. INTRODUCTION

The checklist is mandatory for the installation of loggers and the steps listed in this document are to be completed and signed-off by the electrical contractor.

Contact APD if any query (E-Mail: [Mansour.mohseni@apdpower.com.au](mailto:Mansour.mohseni@apdpower.com.au), P: 9212 1561 & M: 0459 996 022).

Please ensure loggers are sent back within their rental period to avoid incurring additional rental costs.

Refer to item 3.03 for return address.

Electrical Contractor		Name	Joe Swak
Logger Serial No.	201 981		
Site Location	PS 94 Pundoo		
Transformer/Feeder being Logged			
Transformer Tap Setting			
Date and Time	30/3/16	Date and Time	7-4-16
Logging Started	14:00	Logging Completed	12:05
Photo Id#	_____ (Photo after fully installed)		

### IMPORTANT NOTES:

1. Capture logger's installation photos upon initial installation & send to APD on the first day of installation.
2. Check loggers are still logging after a power outage (fully charged battery lasts approx. 30mins on Hioki 3196 and 180mins on Hioki 3198).

## 2. PRE-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Pre-Installation Checklist				
Item	Description	Y	N	N/A
1.01	<i>Ensure the following parts are available, checked and prepared</i>			
	a. HIOKI 3196/3198 PQ logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	b. DC power supply (if applicable) and power cord	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	c. Logger internal battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	d. PC Card memory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	e. Power board with clips/plugs <b><u>Safety Note:</u></b> The power board is to only supply the loggers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	f. Eight test leads with crocodile clips (if only six are supplied, there should be banana plug jumping cables for the neutral connections)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### 3. INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

Installation Checklist				
Item	Description	Y	N	N/A
2.01	Has the safety equipment, including but not limited to, suitable PPE and risk assessment documentation been followed, prepared and checked?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.02	Has the equipment been set up properly and operated as intended on site? This includes: a) ensuring logger is powered up for continuous operation for at least 7 days (the Power Lamp should be Green, if it is Red the meter is operating off of the battery) b) PC Card memory is in the logger and ready ( <u>do not remove</u> – just visually check it is installed)	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
2.03	Have all the phase connector cables been connected properly to logger as per their colour coding (Red, Yellow, Blue for phases and Black for neutral)? Refer to Appendix A.1 and Appendix B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.04	Have the cables been connected to Channel 4 U+ and U- terminals for neutral – earth voltage measurement? <b>Note:</b> U- needs to connect to neutral and U+ to the earth bar (or point) Refer to Appendix A.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.05	Has the 'Start/Stop' button been pressed to trigger the logger? Refer to Appendix A.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.06	Have you ensured that the logger is currently recording the data? Refer to Appendix A.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.07	Has all the equipment been adequately placed and positioned safely to ensure non-interrupted operation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.08	Have clear photos of the fully installed loggers been taken and photo ID noted in the space available at start of this checklist on page 1?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.09	Before leaving site, have the kiosk doors or other means of access been closed and locked appropriately to constraint access?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**\* IMPORTANT NOTE:** Do not adjust, modify or alter settings and configurations of loggers (system) unless specified in this checklist, logging result may differ significantly as a consequence.



## 4. POST-INSTALLATION CHECKLIST

Y = Yes

N = No

N/A = Not Applicable

END OF LOGGING PERIOD				
Item	Description	Y	N	N/A
3.01	Has the logger been turned off by following the correct shutting down procedure? Refer to Appendix A.3 <b>Important note:</b> do not remove the memory card (this is to be processed upon return)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.02	Check all items returned to the associated plastic box and the Tech Rentals checklist is completed Advise APD if any equipment is missing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.03	Transport the Loggers directly back to APD Address at <b>176 Wellington Street, East Perth WA 6004</b> Contact APD on 9212 1561 or 0459 996 022 for any queries on the return of loggers to Perth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This Checklist is to be signed upon completion and returned to APD.

Electrical  
Contractor :

Signature :

Date:

Supervisor:

Signature :

Date:

Comments:.....

.....

.....

## APPENDIX D    Electrical Faults Log for 2015/16 FY


Please refer to the following pages.

NPI UTILITIES INLAND TRANSMISSION INCIDENT LOG											DETAILED INFORMATION			
Date (YYYY/MM/DD)	Generation/Feeder/Distribution Description	Outage Duration (mins)	Time off	Time restored	System Voltage (kV)	Effect on operations	Probable/exact Cause	1SAP notification/s raised	Action/Investigation	1Doc Failure Investigation RPT Link	Fault Current (Amps)	Fault Duration (Seconds)	Syst Frequency during fault (Hz)	Protection Relay that cleared the fault
CLICK HERE TO INSERT NEW EVENT ( 'Enable Content' first)														
2016/01/18	Jimblebar T2 FDR3	116	1855	(a) Energise Bus A (19H32) (b) Energise NP Sub (19H34) (c) Energise Town Sub (19H36) (d) Energise Karnaji Sub ( 19H45) (e) Energise Homestead Creek Sub ( 19H46) (f) Jimblebar Village Sub (19H47) (g) Energise Shovelanna Sub (19H48) (h) Energise Junction Sub (19H56) (i) Energise Whable Back Sub (20H56) (j) Energise South Town Sub (21H05) (k) Energise Hub Sub (21H21) (l) Energise Yandi FDRS (21H27) (m) Energise Jimblebar Sub (22H45)	132/66	Entire Network	Black Out		Revise Procedure for a BLACK START sequence	<a href="http://io1doc/webtop/dri/objectId/0b03c41a825d5823">http://io1doc/webtop/dri/objectId/0b03c41a825d5823</a>				
2016/01/18	NCC872 Jimblebar Mine FDR	118	1637	1835	132/66	Trip of FDR NCC872	Lightning Strike			<a href="http://io1doc/webtop/dri/objectId/0b03c41a825d5704">http://io1doc/webtop/dri/objectId/0b03c41a825d5704</a>	2.75kA	0.6		NCC872
2015/12/17	NCC872 Jimblebar Mine FDR	118	1637	1835	132/66	Trip of FDR NCC872	Lightning Strike			<a href="http://io1doc/webtop/dri/objectId/0b03c41a825d5704">http://io1doc/webtop/dri/objectId/0b03c41a825d5704</a>	2.75kA	0.6		NCC872
2015/12/17	Jimblebar T2 FDR3	116	1310	1506	132/66	Loss of power to FDR 3 & 4	Birdstrike on Pole JM71/501		Grading Study to be done on the Jimblebar Substation	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82553543">http://io1doc/webtop/dri/objectId/0b03c41a82553543</a>	4.8kA	0.58		JIM608 & JIM609
2015/12/8	Yandi FDR 3	484 433	0:28 0:37	(a) - Yandi Primary Crusher (08H32) (b) TLO YD2 (08H56)	33	Loss of power to FDR 3	O/C Trip		Undervoltage caused the capacitor banks to trip and increase current.	<a href="http://io1doc/webtop/component/main?_dmfClientId=1434">http://io1doc/webtop/component/main?_dmfClientId=1434</a>	410A			
2015/12/7	Jimblebar T2 FDR3	515 575 484 433	22:05 0:28 0:37	(a) - OHP1 Primary Crusher 1 (06H40) (b) - OHP1 Primary Crusher 2 (07H39) (c) - Yandi Primary Crusher (08H32) (d) TLO YD2 (08H56)	33	Loss of power to FDR 3 & 4	Birdstrike on Southern Loop		Monitored fire via site contacts Closed when fire intensity reduced	<a href="http://io1doc/webtop/component/main?_dmfClientId=1434">http://io1doc/webtop/component/main?_dmfClientId=1434</a>	~1kA	0.06		
2015/12/2	NP Yandi 132kV Fdr	192	13:37	16:49	132	Loss power to Area C and Yandi	Fire under 132kV line just east of Junction sub		Monitored fire via site contacts Closed when fire intensity reduced	<a href="http://io1doc/webtop/dri/objectId/0b03c41a825078c3">http://io1doc/webtop/dri/objectId/0b03c41a825078c3</a>	~1kA			
2015/9/20	Yandi Feeder 2	62	16:54	17:56	33	Yandi OHL 2	Self clearing fault, bird suspected		Yandi Ops patrolled line. All clear no indication of cause. Successfully reclosed line via SCADA.		3200	0.15		F2-F11-X-P143
2015/07/02	Whaleback 66kV Substation	111	1131	1322	66	Power loss to: - WB Substation - All Whaleback Minesite excluding east	Birdstrike at pole WB-WC71/4	Event:411766138	Bird strike occurred across A phase at pole WB-WC71/4 on the WB-HUB overhead line. WB-HUB protection did not trip due to mal-grading. WB substation incomers tripped and NP FdrB tripped.	<a href="http://io1doc/webtop/dri/objectId/0903c41a8216dbdd">http://io1doc/webtop/dri/objectId/0903c41a8216dbdd</a>	~5kA	0.327	~49.8 Hz	NP 66WL2 WB66 FdrA WB66 FdrB
2015/6/6	Jimblebar Gate House	~40	~1630	~1715	11	Power loss to Jimblebar Gatehouse	Accidental trip during protection system tripping from contractor		From GTS: In the Feeder 3 to Gatehouse Panel, there are MCGG OCEF Protection Relay, and MCSU Sensitive EF (SEF) Protection Relay. We isolated the trip link for MCGG (OCEF) relay, while maintaining MCSU (SEF) relay trip link, in order to keep the backup protection to the system. The MCSU (SEF) relay tripped upon injection test to MCGG relay (OCEF), as it is feeding from the same CT source. It was approximately 40 minutes outage time, before the system was normalised.					
2015/05/05	Yarnima	75 77  75 177 222 227	1700	(a) Newman Town Ship (1639Hrs) (b) Eastern Ridge & Warrawandu Village (1639Hrs) (c) Whaleback (1647) (d) Jimblebar (1841) (e)Area C (1600Hrs) (f) Yandi (2030)	Multiple	Site wide power outages.  Subsequent Whaleback Equipment Failure (Due to voltages)	Yarnima Tripped during testing of ST2. Causing site wide power outage.  Alinta was brought online, possible Voltage Excursions from Alinta Caused damage to Whaleback Fixed Plant Equipment.	EVENT: 411332090 INV: 432017745	ICAM for Incident undertaken results at this stage unknown	<a href="http://io1doc/webtop/dri/objectId/0903c41a82081d8f">http://io1doc/webtop/dri/objectId/0903c41a82081d8f</a>	N/A	N/A	<50Hz	N/A




NPI UTILITIES INLAND DISTRIBUTION INCIDENT LOG																
Event	Notification Number(1SAP)	Date	Time off (GPS/non GPS)	Time restored (GPS/non GPS)	Outage Duration (mins)	Generation/Feeder/Distribution Description	System Voltage	Protection Relay that cleared the fault	Fault Current (Amps)	Fault Duration (Seconds)	Syst Frequency during fault (Hz)	Effect on operations	Probable/exact Cause	Action/Investigation	1Doc Failure Investigation RPT Link	
CLICK HERE TO INSERT NEW EVENT ('Enable Content' first)																
27					0											
26																
25	414071165	2016/06/08	7:56:00	10:16:00	140	South Mine 11kV Feeder	11kV	Transformer Low Oil Trip	N/A	N/A	N/A	No overall impact to supply chain.	Major Oil Leak identified	South Mine was unable to supply the feeders so a back feed was required from the WB 11kV sub.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8286d527">http://io1doc/webtop/dri/objectId/0b03c41a8286d527</a>	
24	414087728	2016/06/08	6:20:00	8:04:00	104	Yandi Feeder 2	33kV	P143 Yandi F2-F11-X	2.9kA	0.02	49.76	No overall impact to supply chain.	Suspect a birdstrike however inspections still required to determine cause of fault.	Site Line patrol was done after the fault. Due heavy rains experienced, there was difficulty in accessing the overhead line routes. It was noticed that a downstream recloser had tripped as well. Line reclose was successful.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8285a950">http://io1doc/webtop/dri/objectId/0b03c41a8285a950</a>	
23	414040599	2016/06/03	10:55:00	2016/06/04 5:24:00 PM	1099	MAC (Junction) Feeder 1	33kV	P143 Junction F1-F11-X	3.3kA	0.6	49.99	Downtime TLO: YD1 - train at OTP (0hrs 56min) MAC TLO - train at OTP - (3hrs 7mins) YD2 - train was loaded with 102 cars (1hr 32min)  Increase in cycle time as a result  No overall impact to supply chain.	Blown insulator at Pole JS13	- Site line patrol conducted - Relay fault reviewed - Reclose successful - By carrying out a protection grading stufy between the Junction Sub to the downstream 33kV relays, the clearance time of the CB may be reduced.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8284930d">http://io1doc/webtop/dri/objectId/0b03c41a8284930d</a>	
22	413830674 / 432465774	2016/03/05	9:17:00	10:14:00	57	Yandi Feeder 2	33kV	F2-Q51 (F2-F11-XP143)	3.1kA	0.1	49.99	- IOWA was isolated to assess the cause of the outage. - Yandi OHP2 Downtime 3hrs 9 mins, Lost Feed Tonnes Ore For Rail (OFR) - 13986	Bird Strike on Overhead line.	- Site line patrol conducted - Relay fault reviewed - Reclose successful	<a href="http://io1doc/webtop/dri/objectId/0b03c41a827c5cab">http://io1doc/webtop/dri/objectId/0b03c41a827c5cab</a>	
21	413717686 / 432445136	2016/04/16	7:24:00	11:21:00	237	Water Bore Feeder	11KV	Water Bore Feeder	6KA	0.5s	-	-Anfo at Whaleback, ER gatehouse, Homestead borefield, ER site potable water	Somebody had thrown chain into overhead line which wrapped around OH earth and hit B phase	432445136 - Isolated line, installed wrap to damaged conductor. Newman Police informed.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82785c4b">http://io1doc/webtop/dri/objectId/0b03c41a82785c4b</a>	
20	413576483 / 413774367	2016/03/25	15:43:00	17:27:00	104	JIMB 33kV FDR 3 & 4	33kV	JIM608 JIM609 JIM806	2.1kA	1.15sec	-		- Probable Bird Strike. - Site line patrol conducted. - Nil fault found.	- Site line patrol conducted - Relay fault reviewed - Reclose successful - Cary out protection study and implement protection changes to rectify mal-grading.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8270b2a8">http://io1doc/webtop/dri/objectId/0b03c41a8270b2a8</a>	
19	413538464 / 432411997	2016/03/20	1:00:00	8:00:00	420	- PS11-PS14. - Red Phase on pole 34/19 blown	11KV	Red Phase Fuse	-	-	-	- Partial loss of power to approx 120 consumers off 4 padsubs PS11-PS14	- Unknown, same fuse has blown previously, cable has been insulation tested OK.	- Noti 413539142 raised to replace the 200A EDO's as they do not make the fuses for them anymore. - PS11 to PS14 now fed off TC4 rather than TC2 until repairs completed	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8271a193">http://io1doc/webtop/dri/objectId/0b03c41a8271a193</a>	
18	413528027	2016/03/18	11:30:00	11:45:00	15	T25 Ethel Creek	11KV	Red Phase Fuse	-	-	-	- Loss of power to approx 20 consumers on Ethel Creek.	LV over head line clash due to branch hitting outer conductor	Event noti raised, 5Y's completed and attached to noti	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8271a192">http://io1doc/webtop/dri/objectId/0b03c41a8271a192</a>	
17	413494087	2016/03/13	19:08:00	23:05:00	237	Yandi Feeder 2	33kV	F2-Q51 (F2-F11-XP143)	2500	0.1055	-	- OHP1: 19H18 to 21H26 (2H08) - OHP3 – Primary Crusher EFE: 19H18 to 23H55 (4H37) - OHP3 – Primary Crusher WFE: 20H27 to 22H14 (1H47) - TLO YD1 – Reclaimer RC640: 19H18 to 23H00 (3H42) - Lost Feed Tonnes: 37489 - There has been no reported direct impact to the supply chain.	- 3 Phase Fault. - Instantaneuos O/C	- 1SAP No. 413178422 – Evaluating respective lines that potentially could have an auto reclose enabled on particular feeders.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a826c8ccd">http://io1doc/webtop/dri/objectId/0b03c41a826c8ccd</a>	
16	413480474	2016/03/10	14:02:00	15:34:00	92	Yandi Feeder 3	33kV	F3-Q51 (F3-F11-XP143)	446	1.618	-	- OHP1: 14H12 to 15H20 (1H08) - OHP3: 14H10 to 16H40 (2H30) - TLO YD2: 15H30 to 17H25 (1H55) - Lost Feed Tonnes: 22696 - There has been no reported direct impact to the supply chain.	- Time O/C trip.	- 1SAP No. 413178422 – Evaluating respective lines that potentially could have an auto reclose enabled on particular feeders. - 1SAP No. 413178421 – Investigate the root cause for the Yandi transmission transformers faulting to MANUAL mode when similar faults occur. Initial findings suspect that the PLC coding is incorrect.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a826c8bfd">http://io1doc/webtop/dri/objectId/0b03c41a826c8bfd</a>	
15	413476525	2016/03/10	2:02:00	5:38:00	216	Junction Mine Feeder 1	33kV	F1-Q21	1640	1.268s	-	Site Wide Power Outage to Mining Area C - OHP1: 02H02 to 08H15 (6H13) - OHP2: 02H02 to 07H31 (5H29) - TLO: 02H02 to 06H29 (4H27) - Lost Feed Tonnes: 46134 - One (1) train diversion to Yandi and queuing at MAC.	- Snake cause B phase to Earth fault on Recloser 1	- Junction Team Investigating. - 1SAP No. 413178422 - Evaluating respective lines that potentially could have an AUTO RECLOSE enabled on particular feeders	<a href="http://io1doc/webtop/dri/objectId/0b03c41a826c8bfc">http://io1doc/webtop/dri/objectId/0b03c41a826c8bfc</a>	
14	413442240	2016/03/05	8:09:00	10:06:00	117	Yandi Feeder 2 (F2)	33kV	Yandi 33kV F2-F11-X143 Micom	1870	65msec	-	Yandi OHP2 and OHP1(tripped on recloser due to Powersation 11/33kV Delta Star step up transformer acting as an earth reference). - YD2 TLO Downtime – 2H46mins. - No direct impact caused to Supply chain.	- Verified bird strike Red Phase to earth fault.	- Yandi HV ops investigating	<a href="http://io1doc/webtop/dri/objectId/0b03c41a826c8bfb">http://io1doc/webtop/dri/objectId/0b03c41a826c8bfb</a>	
13	413391815 / 432385214	2016/02/28	6:00:00	7:00:00	60	TC4 - REC34/64 - Airport	11kV	Pole 34/64 Recloser	-	-	-	Supply down stream of recloser without power.	- Recloser not programmed correctly.	- Auto Recloser is to be reprogrammed and commissioned	<a href="http://io1doc/webtop/dri/objectId/0b03c41a826c8bfa">http://io1doc/webtop/dri/objectId/0b03c41a826c8bfa</a>	

NPI UTILITIES INLAND DISTRIBUTION INCIDENT LOG															1Doc Failure Investigation RPT Link
Event	Notification Number(1SAP)	Date	Time off (GPS/non GPS)	Time restored (GPS/non GPS)	Outage Duration (mins)	Generation/Feeder/Distribution Description	System Voltage	Protection Relay that cleared the fault	Fault Current (Amps)	Fault Duration (Seconds)	Syst Frequency during fault (Hz)	Effect on operations	Probable/exact Cause	Action/Investigation	
12	413361014 / 432379920	2016/02/23	7:19:00	8:13:00	54	STS 6	11kV	STS6	730	.3		Lose of STS 6 Feeder	- Bird Strike	- 1SAP No. 413178422 – Evaluating respective lines that potentially could have an auto reclose enabled on particular feeders. - 1SAP No. 413226278 – Due to previous problems being experience with the SCADA UPS, work is already in progress to replace of the existing UPS.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8268b45f">http://io1doc/webtop/dri/objectId/0b03c41a8268b45f</a>
11	413309585	2016/02/15	12:15:00	13:37:00	82	Junction FDR1	33kV	F1-Q51(F1-F11X)	347.7A			1. Ore For Rail (OFR) Tonnes Lost: 13,818 2. Ore On Rail (OOR) – No train cancellations. 3. No direct impact to the supply chain.	- Time O/C trip. - Area C Cap Banks Out of Service	- Area C production electrical supervisor is to ensure that the capacitor banks are not Out of Service.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82656911">http://io1doc/webtop/dri/objectId/0b03c41a82656911</a>
10	413192999 / 413685954	2016/01/27	17:15:00	17:57:00	42	STS2	11kV	STS2	6700	.121	-	Lose of STS 2 Feeder	- Phase to phase. - Instantaneous O/C Trip. - Lightning Strike	- 1SAP No. 413178422 - Evaluating respective lines that potentially could have an AUTO RECLOSE enabled on particular feeders	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82602ffe">http://io1doc/webtop/dri/objectId/0b03c41a82602ffe</a>
9	413391815 / 432385214	2016/01/27	6:30:00	7:00:00	30	TC4 - REC34/64 - Airport	11kV	Pole 34/64 Recloser	-	-	-	Supply down stream of recloser without power.	- Recloser not programmed correctly.	- Auto Recloser is to be reprogrammed and commissioned	
8	413161817	2016/01/24	16:07:00	17:40:00	93	Whaleback Hubb	66kv	CB703A	2500	-	-		- Fault on South Mine Feeder within Whaleback Distribution.	- 1SAP No. 413233564: Modify the bus zone relay differential current summation logic	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82602f34">http://io1doc/webtop/dri/objectId/0b03c41a82602f34</a>
7	413164055	2016/01/24	16:37:00	17:03:00	26	Yandi feeder 2	33kV	F2-Q51	2800	-	-		- Phase to Phase fault. - Instantaneous O/C trip. - Equipment Failure	- None	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82602ffc">http://io1doc/webtop/dri/objectId/0b03c41a82602ffc</a>
6	413164055	2016/01/24	15:52:00	16:16:00	24	Yandi feeder 2	33kV	F2-Q51	2700	-	-		- Phase to Phase fault. - Instantaneous O/C trip. - Bird strike.	- 1SAP No. 413178422 - Evaluating respective lines that potentially could have an AUTO RECLOSE enabled on particular feeders	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82602ffb">http://io1doc/webtop/dri/objectId/0b03c41a82602ffb</a>
5	413148939	2016/01/22	-	-	5	Recloser 34/38 VT Damaged	11kV	-	-	-	-	None	- Lightning Strike Blew VT	- Order new replacement VT and install. - Recloser to be tested and recommissioned.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82602ffa">http://io1doc/webtop/dri/objectId/0b03c41a82602ffa</a>
4	413152847	2016/01/22	15:36:00	16:13:00	37	Junction Feeder 1	33kV	F1-Q51	3020	-	-		- Birdstrike. - Nil bird found by site	- Site carried out line patrol - Reclosed JIM608	<a href="http://io1doc/webtop/dri/objectId/0b03c41a826030e9">http://io1doc/webtop/dri/objectId/0b03c41a826030e9</a>
3		2016/01/19	6:00:00	7:00:00	60	TC4 - REC34/64 - Airport	11kV	Pole 34/64 Recloser	-	-	-	Supply down stream of recloser without power.	- Recloser not programmed correctly.	- Auto Recloser is to be reprogrammed and commissioned	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82602ff9">http://io1doc/webtop/dri/objectId/0b03c41a82602ff9</a>
2	413125806	2016/01/18	-	-	0	WA8 ABS Repairs	11kV	-	-	-	-	-	- Loose Connection on ABS	- Service ABS & Check for Loose Connections	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82602ffd">http://io1doc/webtop/dri/objectId/0b03c41a82602ffd</a>
1		2016/01/01	11:43:00	12:40:00	57	Jimblebar 33kV Feeder No.4 (JIM608)	33kV	JIM608	IA: 292A IB: 2158A IC: 2086A IG: 2227A	905msec	-	Jimblebar TLO shutdown	- Birdstrike. Nil bird found by site	- Site carried out line patrol - Reclosed JIM608	<a href="http://io1doc/webtop/dri/objectId/0b03c41a825807db">http://io1doc/webtop/dri/objectId/0b03c41a825807db</a>
31	412930221 / 432298507	2015/12/18	12:00:00	19:30:00	450	15 Wilara - Red phase out on house - no a/c or power to half house	415V						Red phase fuse holder burnt out	replaced fuse holder	
30	412898565 / 432292759	2015/12/14	2:30:00	3:00:00	30	PS25 Feeder	LV	CB				Loss to Laver and willis street	Overcurrent	Change CB Settings to 0.8 I from 0.63	
29	412869936 / 432286753	2015/12/10	5:30:00	7:00:00	90	TC4 - REC34/37 - Airport	11kV	Pole 34/37 Recloser	A-B Phase O/C Trip			Loss power to partial east Newman & airpot	Possible Bird Strike/ Unknown	Engineering to find out if 1 shot on recloser	
28	412815614 / 432276976	2015/12/02	16:30:00	18:30:00	120	3&5 Keedi Street	415V					Nil	Reported that OH service to 5 Keedi blown off consumer pole - hit by tree in storm No loss of supply	require tree to be trimmed and service put back onto consumer pole rasied noti for repairs to raiser bracket and pole 412820925	
27	412815702 / 432276978	2015/12/02	16:42:00	18:17:00	95	Water Bores 11kV Line	11kV	TS WB	IA: 4.8kA IB: 267A IC: 5.6kA Io: 708A	90msec		Loss power to: Eastern Ridge Gatehouse Homestead Ck Bores Newman Waste Water Plant Ore Body 25 Newman Racecourse Camp Drafting	Disc insulator failure at pole WB8 (adjacent to FMG plant) during a storm	Patrolled line and identified fault Isolated damaged section Close TS WB feeder Backfed OB25 from Homestead Ck	<a href="http://io1doc/webtop/dri/objectId/0b03c41a825078c4">http://io1doc/webtop/dri/objectId/0b03c41a825078c4</a>
26	412811746 / 432278007	2015/12/02	4:56:00	6:21:00	85	TC4 - East Newman & Airport	11kV	Pole 34/37 Recloser	A-B Phase O/C Trip			Loss power to partial east Newman & airpot	Correla carcass found under airpot line near pole 34/60	Nil trip TC4 in Town Substation TC4 in TS recorded I> event P34/37 recloser reclosed locally	<a href="http://io1doc/webtop/dri/objectId/0b03c41a82503e43">http://io1doc/webtop/dri/objectId/0b03c41a82503e43</a>
25		2015/11/29				Shovelanna									
24		2015/11/28	14:00:00			PS26 LV Feeder	415V	MCCB				Loss 415V Distribution			
23	412737980 / 432262848	2015/11/20	15:52:00	17:40:00	108	Southtown STS6	11KV	Micom P127	A ph: 336A B ph: 838A C ph: 309A	400msec		All STS6 & TC3 TC3 tied to STS6 due to TC3 fault	Pole 35/35 DOFs W ph blown. Wire expelled and shorted to pole. This was the tie between STS6 and tC3. DOF fatigued during previous day TC3 fault.	Police reported seeing sparks on line. Found blown W ph DOF at pole 35/25 and arcing marks from fuse wire on cross arm. Opened pole 35/35 ABS and reclosed STS6. Recloser 31/46/1A tripped on earth fault. Opened P35/35 fdr at RMU8 Closed recloser 31/46/1A	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8249f84f">http://io1doc/webtop/dri/objectId/0b03c41a8249f84f</a>
22	412850469 / 432283474	2015/11/19	17:20:00			Camp Drafting Line (off water bores line)	11kV	DOFs Pole WB9	?	?		Outage of camp drafting area	Earth wire fallen on line. Storm with lots of flying objects.	Outage reported by local. Line patrolled and defect found. Line isolated.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8249f84e">http://io1doc/webtop/dri/objectId/0b03c41a8249f84e</a>
21	412850415 / 432283470	2015/11/19	17:20:00	18:40:00	80	Town Sub - TC3 & RMU01	11kV	Micom - P127 Sepam	TC3 A ph: 1377kA TC3 B ph: 4.96 TC3 C ph: 2.47	125msec		STS6 and TC3 tied at time of fault. Outage at P5104/105/106/108 Visible dip on network	TC3 Earth wire fallen onto A phase beside Kurra Camp. Storm with lots of flying objects.	Line patrolled. Attempted reclose. Line patrolled again and found fault. Kurra ring opened at P5108 and ring closed. Earth wire repaired 21/11/2015. Network returned to normal config.	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8249f3ec">http://io1doc/webtop/dri/objectId/0b03c41a8249f3ec</a>
20		2015/11/16	10:59:00	14:10:00	191	Jmb JIM608 (FDR No.4)	33kv	Multilin	A phase 12kA / 6.2kA B phase 278A / 6.3kA C phase 72A / 6.1kA	630msec		Loss power JMB Fdr4 Overvoltage trip Whaleback 11kV and 6.6kV Multiple OV trips in other plant MCCs Yarnima GT2 trip over freq Yarnima GT3 & ST1 stayed on Alint GT trip reverse power	Nil cause reported by site (JMB). Waveform looks like bird strike	0msec - A Ph to earth fault Jmb Fdr4 - 12kA 124msec - Fault develop to 3 ph - 6.2kA 565msec - JIM608 relay initiates Phase TOC1 trip 630msec - JIM608 CB opens / clears fault >630msec - 132kV voltage increase to 153kV	<a href="http://io1doc/webtop/dri/objectId/0b03c41a8249f3eb">http://io1doc/webtop/dri/objectId/0b03c41a8249f3eb</a>
19		2015/10/12	11:00:00	12:07:00	67	Ynd Fdr2 (F2-F11/X)	33kV	Micom P127	A Phae - 118A B Phase - 30A C Phase - 3129A	61msec	N/A	Loss of power to Yandi site Fdr2	Line patrol by site found nil faults	Yandi site patrolled line & found nil faults NPI downloaded fault record NPI closed Fdr2 when requested by Yandi	<a href="http://io1doc/webtop/dri/objectId/0b03c41a823f232b">http://io1doc/webtop/dri/objectId/0b03c41a823f232b</a>
18		2015/10/10	16:11:00	17:05:00	54	JIM608	33kV	GE F60		N/A	N/A	Loss of power to parts of Jimblebar Mine site.	3 Phase TOC trip.Reports of high winds & lightning in the area	Reclose of JIM608 was done after line was patrolled and no faults identified.	

								SAIDI/SAIFI Calculations								
Event	Notification Number(1SAP)	Date	Time off (GPS/non GPS)	Time restored (GPS/non GPS)	Outage Duration (mins)	Generation/Feeder/Distribution Description	System Voltage	Substation	Feeder	TX	Total Consumers affected	Fduration (From column C)	SAIDI Mins/Cust	SAIFI	SAIDI Mins/Cust TOTAL ('06/2015 - '06/2016)	SAIFI TOTAL ('06/2015 - '06/2016)
CLICK HERE TO INSERT NEW EVENT ('Enable Content' first)											0	0	0.0	0.00	66.9	0.81
27					0						0	0	0.0	0.00		
26											0	0	0.0	0.00		
25	414071165	2016/06/08	7:56:00	10:16:00	140	South Mine 11kV Feeder	11kV				1	140	0.1	0.00		
24	414087728	2016/06/08	6:20:00	8:04:00	104	Yandi Feeder 2	33kV				1	104	0.0	0.00		
23	414040599	2016/06/03	10:55:00	2016/06/04 5:24:00 PM	1099	MAC (Junction) Feeder 1	33kV				1	1099	0.5	0.00		
22	413830674 / 432465774	2016/03/05	9:17:00	10:14:00	57	Yandi Feeder 2	33kV				1	57	0.0	0.00		
21	413717686 / 432445136	2016/04/16	7:24:00	11:21:00	237	Water Bore Feeder	11KV		Water Bore	Newman Sewerage Pl	10	237	1.0	0.00		
20	413576483 / 413774367	2016/03/25	15:43:00	17:27:00	104	JIMB 33kV FDR 3 & 4	33kV				1	104	0.0	0.00		
19	413538464 / 432411997	2016/03/20	1:00:00	8:00:00	420	- PS11-PS14. - Red Phase on pole 34/19 blown	11KV			PS11 - PS14	76	420	13.4	0.03		
18	413528027	2016/03/18	11:30:00	11:45:00	15	T25 Ethel Creek	11KV			T25	27	15	0.2	0.01		
17	413494087	2016/03/13	19:08:00	23:05:00	237	Yandi Feeder 2	33kV				1	237	0.1	0.00		
16	413480474	2016/03/10	14:02:00	15:34:00	92	Yandi Feeder 3	33kV				1	92	0.0	0.00		
15	413476525	2016/03/10	2:02:00	5:38:00	216	Junction Mine Feeder 1	33kV				1	216	0.1	0.00		
14	413442240	2016/03/05	8:09:00	10:06:00	117	Yandi Feeder 2 (F2)	33kV				1	117	0.0	0.00		
13	413391815 / 432385214	2016/02/28	6:00:00	7:00:00	60	TC4 - REC34/64 - Airport	11kV			TC4 - REC34/64 - Airport	3	60	0.1	0.00		



								SAIDI/SAIFI Calculations								
Event	Notification Number(1SAP)	Date	Time off (GPS/non GPS)	Time restored (GPS/non GPS)	Outage Duration (mins)	Generation/Feeder/Distribution Description	System Voltage	Substation	Feeder	TX	Total Consumers affected	Fduration (From column C)	SAIDI Mins/Cust	SAIFI	SAIDI Mins/Cust TOTAL ('06/2015 - '06/2016)	SAIFI TOTAL ('06/2015 - '06/2016)
12	413361014 / 432379920	2016/02/23	7:19:00	8:13:00	54	STS 6	11kV		STS6		211	54	4.8	0.09		
11	413309585	2016/02/15	12:15:00	13:37:00	82	Junction FDR1	33kV				1	82	0.0	0.00		
10	413192999 / 413685954	2016/01/27	17:15:00	17:57:00	42	STS2	11kV		STS2		567	42	10.0	0.24		
9	413991815 / 432385214	2016/01/27	6:30:00	7:00:00	30	TC4 - REC34/64 - Airport	11kV			TC4 - REC34/64 - Airport	3	30	0.0	0.00		
8	413161817	2016/01/24	16:07:00	17:40:00	93	Whaleback Hubb	66kv				1	93	0.0	0.00		
7	413164055	2016/01/24	16:37:00	17:03:00	26	Yandi feeder 2	33kV				1	26	0.0	0.00		
6	413164055	2016/01/24	15:52:00	16:16:00	24	Yandi feeder 2	33kV				1	24	0.0	0.00		
5	413148939	2016/01/22	-	-	5	Recloser 34/38 VT Damaged	11kV				0	5	0.0	0.00		
4	413152847	2016/01/22	15:36:00	16:13:00	37	Junction Feeder 1	33kV				1	37	0.0	0.00		
3		2016/01/19	6:00:00	7:00:00	60	TC4 - REC34/64 - Airport	11kV			TC4 - REC34/64 - Airport	3	60	0.1	0.00		
2	413125806	2016/01/18	-	-	0	WA8 ABS Repairs	11kV				0	0	0.0	0.00		
1		2016/01/01	11:43:00	12:40:00	57	Jimblebar 33kV Feeder No.4 (JIM608)	33kV				1	57	0.0	0.00		
31	412930221 / 432298507	2015/12/18	12:00:00	19:30:00	450	15 Wilara - Red phase out on house - no a/c or power to half house	415V				1	450	0.2	0.00		
30	412898565 / 432292759	2015/12/14	2:30:00	3:00:00	30	PS25 Feeder	LV			PS25	20	30	0.3	0.01		
29	412869936 / 432286753	2015/12/10	5:30:00	7:00:00	90	TC4 - REC34/37 - Airport	11kV			TC4 - REC34/37 - Airport	3	90	0.1	0.00		
28	412815614 / 432276976	2015/12/02	16:30:00	18:30:00	120	3&5 Keedi Street	415V				2	120	0.1	0.00		
27	412815702 / 432276978	2015/12/02	16:42:00	18:17:00	95	Water Bores 11kV Line	11kV		Water Bore		3	95	0.1	0.00		
26	412811746 / 432278007	2015/12/02	4:56:00	6:21:00	85	TC4 - East Newman & Airport	11kV		TC4		152	85	5.4	0.06		
25		2015/11/29				Shovelanna					0	0	0.0	0.00		
24		2015/11/28	14:00:00			PS26 LV Feeder	415V				0	0	0.0	0.00		
23	412737980 / 432262848	2015/11/20	15:52:00	17:40:00	108	Southtown STS6	11KV		STS6		211	108	9.6	0.09		
22	412850469 / 432283474	2015/11/19	17:20:00			Camp Drafting Line (off water bores line)	11kV				1	0	0.0	0.00		
21	412850415 / 432283470	2015/11/19	17:20:00	18:40:00	80	Town Sub - TC3 & RMU01	11kV		TC3		610	80	20.5	0.26		
20		2015/11/16	10:59:00	14:10:00	191	Jmb JIM608 (FDR No.4)	33kv				1	191	0.1	0.00		
19		2015/10/12	11:00:00	12:07:00	67	Ynd Fdr2 (F2-F11/X)	33kV				1	67	0.0	0.00		
18		2015/10/10	16:11:00	17:05:00	54	JIM608	33kV				1	54	0.0	0.00		