

15 Operation

All mobile plant is to have a documented or electronically recorded daily inspection completed by the operator once every 24 hours when the vehicle is being used.

All mobile plant operators are to complete a pre use / walk around inspection prior to operation.

All mobile plant is only to be operated within its design limits / intended use.

16.1.3 Fire Protection Service Schedules

As a minimum the following routine service schedules apply for pre-engineered / engineered systems in accordance with AS5062 and AS1851:

- Daily inspection by the operator
- Six (6) monthly routine service
- Twelve (12) monthly routine service
- Five (5) yearly routine service
- Ten (10) yearly routine service

As a minimum the following routine service schedules apply for gaseous systems in accordance with AS 5062 and AS 1851 with the exception of systems fitted in axle boxes of haul truck which will be serviced in accordance with the requirements of above for engineered systems:

- Daily inspection by the operator
- Monthly routine service
- Six (6) monthly routine service
- Twelve (12) monthly routine service
- Five (5) yearly routine service
- Ten (10) yearly routine service

As a minimum the following routine service schedules apply for fire extinguisher in accordance with AS5062 and AS1851:

- Daily inspection by the operator
- Three (3) monthly routine service
- Six (6) monthly routine service
- Twelve (12) monthly routine service
- Three (3) yearly routine service (due to harsh environment)

Service intervals should be reviewed to confirm adequacy.

All cylinders are to be inspected and tested in accordance with AS2030.5 Gas cylinders.

The preferred fire system maintainer shall maintain an electronic register of all fire protection equipment for site.