

7.6 Labelling

- Manufacturer's labels shall be a minimum standard as provided in the National Code of Practice for the Labelling of Workplace Substances [NOHSC:2012 (1994)]. These labels must be maintained on the vessel or packaging.
- Piping shall be clearly labelled such that the contents and direction of flow can be identified according to AS1345-1995 – Identification of the contents of pipes, ducts and conduits (Appendix 2).
- If there is a requirement to decant any product into a smaller or substitute container that second container must also be labelled in accordance with the National Code of Practice for the Labelling of Workplace Substances [NOHSC:2012 (1994)].
- No hazardous materials shall be decanted into food or drink containers or previously labelled containers or vessels.
- Labels on all hazardous materials containers must be maintained in a serviceable condition so that the information remains legible. The integrity of chemical containers must be retained, and when redundant, containers must be disposed of as described by the substance SDS (Refer section 5.9).
- Labels can be created in the ChemAlert system. Contact the department or site hazardous materials coordinator for guidance.



Document Reference - MAC-STE-PRO-013